

Package: comf (via r-universe)

September 15, 2024

Type Package

Title Models and Equations for Human Comfort Research

Version 0.1.12

Date 2024-01-29

Imports plyr, graphics, reshape, jsonlite

Maintainer Marcel Schweiker <mschweiker@ukaachen.de>

Description Calculation of various common and less common comfort indices such as predicted mean vote or the two node model. Converts physical variables such as relative to absolute humidity and evaluates the performance of comfort indices.

License GPL-2

LazyLoad yes

LazyData true

Suggests R.rsp

VignetteBuilder R.rsp

RoxygenNote 7.2.3

Encoding UTF-8

Repository <https://marcelschweiker.r-universe.dev>

RemoteUrl <https://github.com/marcelschweiker/comf>

RemoteRef HEAD

RemoteSha cece40585bb35baa325435cedc03030b65e69337

Contents

comf-package	3
calc2Node	4
calcAD	6
calcaPMV	7
calcATHBpmv	9
calcATHBpmv2015	10

calcATHBpts	11
calcATHBset	12
calcATHBstandard	14
calcATHBx	15
calcAvgAcc	16
calcBias	17
calcCE	19
calcComfInd	20
calcDisc	22
calcdTNZ	24
calcepCoeff	26
calcePMV	27
calcET	29
calcHbExSteady	31
calcHbExUnsteady	33
calcIREQ	36
calcIso7933	38
calcMixR	41
calcMRTglobe	43
calcPD	44
calcPMV	45
calcPMVadj	47
calcPMVGagge	48
calcPMVPPD	49
calcPMVStar	51
calcPPD	52
calcPS	54
calcPTS	55
calcPtsa	57
calcPtse	59
calcRT	61
calcSET	62
calcSkinWettedness	64
calcSolarGain	65
calctAdaptI5251	67
calcTNZPDF	68
calcTPRTSV	71
calcTroin	72
calcTSens	73
calcTWC	75
calcUTCI	76
calcVTG	77
createCond	78
cutTSV	79
dfASHRAETableG11	80
dfField	81
dfISO7730AppE	82
dfISO7730TableD1	83

dfISO7933AppF	84
dfUTCIVvalues	85

Index	86
--------------	-----------

comf-package	<i>Calculation and Evaluation of Common and Less Common Comfort Indices</i>
--------------	---

Description

This package contains several functions to calculate and evaluate a series of comfort indices.

Details

```

Package:    comf
Type:      Package
Version:   0.1.12
Date:      2024-01-29
License:   GPL-2
LazyLoad:  yes

```

To create input parameters, the function `createCond`, which creates a list of input parameters may be helpful. The main function of this packages is `calcComfInd`, which returns the desired comfort parameters. However, each index can be computed using its own function, e.g. to calculate only PMV the function `calcPMV` can be used.

The comfort indices calculated within this package are for example as follows. To get further information, go to the help page, which can be accessed using the index below e.g. `?pmv`:

Index	Description
<code>pmv</code>	Predicted mean vote (PMV)
<code>ppd</code>	Predicted percentage dissatisfied (PPD)
<code>tnHumphreysNV</code>	Neutral temperature in naturally ventilated buildings according to Humphreys 1978
<code>tnHumphreysAC</code>	Neutral temperature in climate-controlled buildings according to Humphreys 1978
<code>tnAuliciems</code>	Neutral temperature according to Auliciems 1981
<code>tAdapt15251</code>	Adaptive comfort temperature according to EN 15251
<code>dTNZ</code>	Distance to thermoneutral zone
<code>ATHBpmv</code>	Adaptive thermal heat balance vote based on pmv
<code>ATHBset</code>	Adaptive standard effective temperature
<code>ATHBpts</code>	Adaptive thermal heat balance vote based on set
<code>apmv</code>	Adaptive predicted mean vote according to Yao et al.
<code>ptsa</code>	Adaptive predicted thermal sensation vote according to Gao et al.
<code>epmv</code>	PMV adjusted with expectancy factor based on Fanger and toftum
<code>ptse</code>	Predicted thermal sensation vote based on set and adjusted with expectancy factor according to Gao et al.
<code>set</code>	standard effective temperature based on two node model by Gagge et al.
<code>et</code>	Effective temperature based on two node model by Gagge et al.

tsens	Predicted thermal sensation
disc	Predicted discomfort
ps	Predicted percentage satisfied with the level of air movement
pd	Predicted percentage dissatisfied due to draft
pts	Predicted thermal sensation vote based on set
HBxst	Human body exergy consumption rate using steady state method
PHS	Predicted heat strain

The performance criteria included in this package are presented below. Again you can get further information on the corresponding help pages:

Index	Description
meanBias	Mean bias between predicted and observed thermal sensation vote
TPR	True positive rate
avgAcc	Average accuracy of predicted thermal sensation vote

Author(s)

Marcel Schweiker in cooperation with Sophia Mueller and many others.

Contact: mschweiker@ukaachen.de

References

See references in function descriptions.

See Also

see also [createCond](#), [calcComfInd](#)

calc2Node

Comfort Indices based on the 2-Node-Model

Description

calc2Node calculates Comfort Indices based on the 2-Node-Model by Gagge et al.

Usage

```
calc2Node(ta, tr, vel, rh, clo = 0.5, met = 1, wme = 0, sa = NULL, pb = 760,
ltime = 60, ht = 171, wt = 70, tu = 40, obj = "set", csw = 170, cdil = 120,
cstr = 0.5, varOut = "else", bodyPosition = 'sitting')
```

Arguments

ta	a numeric value presenting air temperature in [degree C]
tr	a numeric value presenting mean radiant temperature in [degree C]
vel	a numeric value presenting air velocity in [m/s]
rh	a numeric value presenting relative humidity [%]
clo	a numeric value presenting clothing insulation level in [clo]
met	a numeric value presenting metabolic rate in [met]
wme	a numeric value presenting external work in [met]
sa	(optional) surface Area according to mosteller formula [m ²]
pb	a numeric value presenting barometric pressure in [torr] or [mmHg]
ltime	a numeric value presenting exposure time in [minutes]
ht	a numeric value presenting body height in [cm]
wt	a numeric value presenting body weight in [kg]
tu	a numeric value presenting turbulence intensity in [%]
obj	a character element, either "set" or "pmvadj"
csw	a numeric value presenting the driving coefficient for regulatory sweating
cdil	a numeric value presenting the driving coefficient for vasodilation
cstr	a numeric value presenting the driving coefficient for vasoconstriction
varOut	a string value either "else" for normal output of SET or "skinWet" to report value of skin wettedness
bodyPosition	a string representing body position, has to be 'sitting' or 'standing'. Default value is 'sitting'

Details

All variables must have the same length 1. For the calculation of several values use function calcComfInd. The value of obj defines whether the function will use the version presented in ASHRAE 55-2013 for adjustment of pmv (obj = "pmvadj"), or the original code by Gagge to calculate set (obj = "set"). In the version presented in ASHRAE 55-2013, the lines of code related to self-generated convection is deleted. Therefore, a difference can only be seen at higher values of met.

Value

returns a data.frame with the following items:

et - **Effective temperature**

tsens - **Predicted thermal sensation**

disc - **Predicted discomfort**

ps - **Predicted percentage satisfied with the level of air movement**

pd - **Predicted percentage dissatisfied due to draft**

pts - **Predicted thermal sensation vote based on set**

pmvg – Gagge’s version of Fanger’s PMV

pmvstar – Same as Fanger’s PMV except that dry is calculated using SET* rather than the operative temperature

The other functions return a single index, e.g. code(calcSET) returns the standard effective temperature.

Note

In case one of the variables is not given, a standard value will be taken from a list (see [createCond](#) for details).

Author(s)

The code for calc2Node is based on the code in BASIC and C++ presented by Fountain and Huizenga (1995). The translation into R-language and comparison with ASHRAE 55-2013 conducted by Marcel Schweiker.

References

ASHRAE Standard 55-2013. Thermal environmental conditions for human occupancy. American society of heating, Refrigerating and Air-Conditioning Engineering, Atlanta, USA, 2013.

Fountain & Huizenga (1995) A thermal sensation model for use by the engineering profession ASHRAE RP-781 Final report.

Gagge, Fobelets & Berglund (1986) A standard predictive index of human response to the thermal environment, ASHRAE transactions, 92 (2B), 709-731.

See Also

see also [calcComfInd](#)

Examples

```
## Calculation of a single set of values.  
calc2Node(22, 25, .50, 50)
```

calcAD

PPD with Ankle Draft

Description

Function to calculate ankle draft using the predicted percentage of dissatisfied.

Usage

```
calcAD(ta, tr, vel, rh, clo, met, vAnkle)
```

Arguments

ta	a numeric value presenting air temperature in [degree C]
tr	a numeric value presenting mean radiant temperature in [degree C]
vel	a numeric value presenting air velocity in [m/s]
rh	a numeric value presenting relative humidity [%]
clo	a numeric value presenting clothing insulation level in [clo]
met	a numeric value presenting metabolic rate in [met]
vAnkle	air speed at the 0.1 m (4 in.) above the floor [m/s]

Details

Calculates the percentage of thermally dissatisfied people with the ankle draft (0.1 m) above floor level. This equation is only applicable for velocity < 0.2 m/s (40 fps)

Value

Predicted Percentage of Dissatisfied occupants with ankle draft in [%]
Acceptability in [boolean]

Author(s)

Code implemented in to R by Shoaib Sarwar. Further contribution by Marcel Schweiker.

References

Original code in Python by Tartarini & Schiavon (2020) <doi:10.1016/j.softx.2020.100578>

Examples

```
calcAD(25,25,0.2,50,0.5,1.2,0.3) # returns Ankle_draft_ppd:18.6, Acceptability:TRUE
```

calcaPMV

Adaptive Predicted Mean Votes

Description

Function to calculate adaptive Predicted Mean Vote (aPMV) adjusted through the adaptive coefficient.

Usage

```
calcaPMV(ta, tr, vel, rh, clo = 0.5, met = 1, wme = 0, apCoeff)
```

Arguments

ta	a numeric value presenting air temperature in [degree C]
tr	a numeric value presenting mean radiant temperature in [degree C]
vel	a numeric value presenting air velocity in [m/s]
rh	a numeric value presenting relative humidity [%]
clo	a numeric value presenting clothing insulation level in [clo]
met	a numeric value presenting metabolic rate in [met]
wme	a numeric value presenting external work in [met]
apCoeff	adaptive coefficient lambda

Details

apCoeff can be derived using `calcapCoeff`.

Value

calcaPMV returns the predicted mean vote adjusted through the adaptive coefficients.

Note

In case one of apCoeff is not given, a standard value will be taken from a list (see `createCond` for details).

Author(s)

Code implemented in to R by Marcel Schweiker. Further contribution by Sophia Mueller and Shoaib Sarwar.

References

aPMV is based on Yao, Li and Liu (2009) <doi:10.1016/j.buildenv.2009.02.014>

See Also

[calcComfInd](#), [calcapCoeff](#)

Examples

```
## Note. Due to random generated asv values. The values for the coefficients will not be meaningful.
## Create sample data
ta <- 20:24 # vector with air temperature values
tr <- ta # vector with radiant temperature values
vel <- rep(.1,5) # vector with air velocities
rh <- rep(50,5) # vector with relative humidity values
clo <- rep(1.0,5) # vector with clo values
met <- rep(1.1,5) # vector with metabolic rates
asv <- rnorm(5) # vector with actual sensation votes
lsCond <- as.list(data.frame(ta, tr, vel, rh, clo, met, asv))
```



```

## Calculate coefficient apCoeff for data set
apCoeff <- calcapCoeff(lsCond)
## calculate apmv
apmv <- NULL
for (i in 1:length(ta)){
  apmv[i] <- calcaPMV(ta[i], tr[i], vel[i], rh[i], clo[i], met[i], apCoeff = apCoeff)$apmv}
apmv

```

calcATHBpmv	<i>PMV based on Adaptive Thermal Heat Balance Framework of multiple Models</i>
-------------	--

Description

calcATHBpmv calculates the PMV based on adaptive thermal heat balance framework based on the newest version (2022)

Usage

```

calcATHBpmv(trm, ta, tr, vel, rh, met,
coolingStrategyBuilding = 'naturallyventilated',
buildingTypeSimple = 'office', seasonSimple = 'spring')

```

Arguments

trm	- Running mean outdoor temperature in [degree C]
ta	- a numeric value presenting air temperature in [degree C]
tr	- a numeric value presenting mean radiant temperature in [degree C]
vel	- a numeric value presenting air velocity in [m/s]
rh	- a numeric value presenting relative humidity [%]
met	- a numeric value presenting metabolic rate in [met]
coolingStrategyBuilding	- the process in which the building was ventilated. Value can be among Mixed Mode', 'Naturally Ventilated' as a String
buildingTypeSimple	- simple building type. Value can be among Multifamily housing, Office as a string
seasonSimple	- season. Value can be among 'Spring', 'Summer', 'Winter' as a String

Details

aliases athb ATHB calcATHBPmvModel1, calcATHBPmvModel2, calcATHBPmvModel3

Value

calcATHBpmv an array of PMV values of different models adapted through the ATHB approach

Author(s)

Code implemented in to R by Shaomi Rahman. Further contribution by Marcel Schweiker.

References

Schweiker & Wagner (2015) <doi:10.1016/j.buildenv.2015.08.018> Schweiker (2022) <doi:10.1111/ina.13018>

See Also

see also [calcComfInd](#), [link{calcATHBpts}](#), [link{calcATHBset}](#),
[link{calcATHBpmv2015}](#), [link{calcATHBPmvModel1}](#), [link{calcATHBPmvModel2}](#), [link{calcATHBPmvModel3}](#)

Examples

```
calcATHBpmv(20, 25, 25, .1, 50, 1.1, 'naturallyventilated','office',
'spring')
```

calcATHBpmv2015

PMV based on Adaptive Thermal Heat Balance Framework

Description

calcATHBpmv2015 calculates the PMV based on adaptive thermal heat balance framework based on the original method published 2015

Usage

```
calcATHBpmv2015(trm, psych, ta, tr, vel, rh, met, wme = 0)
```

Arguments

trm	- Running mean outdoor temperature in [degree C]
psych	- factor related to fixed effect on perceived control
ta	- a numeric value presenting air temperature in [degree C]
tr	- a numeric value presenting mean radiant temperature in [degree C]
vel	- a numeric value presenting air velocity in [m/s]
rh	- a numeric value presenting relative humidity [%]
met	- a numeric value presenting metabolic rate in [met]
wme	- a numeric value presenting external work in [met]

Details

aliases athb2015 ATHB2015 athbOld ATHBOLD

All variables must have the same length 1. For the calculation of several values use function calcComfInd.

Value

calcATHBpmv2015 PMV value adapted through the ATHB approach

Author(s)

Marcel Schweiker

References

Schweiker & Wagner (2015) <doi:10.1016/j.buildenv.2015.08.018> Schweiker & Wagner (2016) Exploring potentials and limitations of the adaptive thermal heat balance framework Proceedings of 9th Windsor Conference: making comfort relevant Cumberland Lodge, Windsor, UK, 2016

See Also

see also [calcComfInd](#), [link{calcATHBpts}](#), [link{calcATHBset}](#)

Examples

```
calcATHBpmv2015(20, 0, 25, 25, .1, 50, 1.1)
```

calcATHBpts	<i>Predicted Thermal Sensation by Gagge using Adaptive Thermal Heat Balance approach</i>
-------------	--

Description

calcATHB calculates predicted thermal sensation based on the adaptive thermal heat balance approach using Gagge's 2 Node Model

Usage

```
calcATHBpts(trm, psych, ta, tr, vel, rh, met, wme = 0, pb = 760,
            ltime = 60, ht = 171, wt = 69.9)
```

Arguments

trm	- Running mean outdoor temperature in [degree C]
psych	- factor related to fixed effect on perceived control
ta	- a numeric value presenting air temperature in [degree C]
tr	- a numeric value presenting mean radiant temperature in [degree C]
vel	- a numeric value presenting air velocity in [m/s]
rh	- a numeric value presenting relative humidity [%]
met	- a numeric value presenting metabolic rate in [met]
wme	- a numeric value presenting external work in [met]

pb	- a numeric value presenting barometric pressure in [torr] or [mmHg]
ltime	- a numeric value presenting exposure time in [minutes]
ht	- a numeric value presenting body height in [cm]
wt	- a numeric value presenting body weight in [kg]

Details

All variables must have the same length 1. For the calculation of several values use function `calcComfInd`.

Value

`calcATHBpts` returns the predicted thermal sensation adapted through the ATHB approach

Author(s)

Marcel Schweiker

References

Schweiker & Wagner (2015) <doi:10.1016/j.buildenv.2015.08.018> Schweiker & Wagner (2016) Exploring potentials and limitations of the adaptive thermal heat balance framework Proceedings of 9th Windsor Conference: making comfort relevant Cumberland Lodge, Windsor, UK, 2016

See Also

see also [calcComfInd](#), [link{calcATHBpmv}](#), [link{calcATHBset}](#)

Examples

```
calcATHBpts(20, 0, 25, 25, .1, 50, 1.1, 0, 760, 60, 171, 70)
```

calcATHBset

SET based on Adaptive Thermal Heat Balance Framework

Description

Calculation of SET based on Adaptive Thermal Heat Balance framework using Gagge's 2-node model

Usage

```
calcATHBset(trm, psych, ta, tr, vel, rh, met, wme = 0, pb = 760,  
            ltime = 60, ht = 171, wt = 69.9)
```

Arguments

trm	- Running mean outdoor temperature in [degree C]
psych	- factor related to fixed effect on perceived control
ta	- a numeric value presenting air temperature in [degree C]
tr	- a numeric value presenting mean radiant temperature in [degree C]
vel	- a numeric value presenting air velocity in [m/s]
rh	- a numeric value presenting relative humidity [%]
met	- a numeric value presenting metabolic rate in [met]
wme	- a numeric value presenting external work in [met]
pb	- a numeric value presenting barometric pressure in [torr] or [mmHg]
ltime	- a numeric value presenting exposure time in [minutes]
ht	- a numeric value presenting body height in [cm]
wt	- a numeric value presenting body weight in [kg]

Details

All variables must have the same length 1. For the calculation of several values use function `calcComfInd`.

Value

ATHBset set value adapted through the ATHB approach

Author(s)

Marcel Schweiker

References

Schweiker & Wagner (2015) <doi:10.1016/j.buildenv.2015.08.018> Schweiker & Wagner (2016) Exploring potentials and limitations of the adaptive thermal heat balance framework Proceedings of 9th Windsor Conference: making comfort relevant Cumberland Lodge, Windsor, UK, 2016

See Also

see also [calcComfInd](#), [link{calcATHBpmv}](#), [link{calcATHBpts}](#)

Examples

```
calcATHBset(20, 0, 25, 25, .1, 50, 1.1, 0, 760, 60, 171, 70)
```

calcATHBstandard *PMV based on Adaptive Thermal Heat Balance Framework for the Standard Model*

Description

calcATHBstandard calculates the PMV based on adaptive thermal heat balance framework based on the newest version (2022)

Usage

```
calcATHBstandard(trm, ta, tr, vel, rh, met)
```

Arguments

trm	- Running mean outdoor temperature in [degree C]
ta	- a numeric value presenting air temperature in [degree C]
tr	- a numeric value presenting mean radiant temperature in [degree C]
vel	- a numeric value presenting air velocity in [m/s]
rh	- a numeric value presenting relative humidity [%]
met	- a numeric value presenting metabolic rate in [met]

Details

aliases athb ATHB

Value

calcATHBstandard PMV value adapted through the ATHB approach with standard model

Author(s)

Code implemented in to R by Shaomi Rahman. Further contribution by Marcel Schweiker.

References

Schweiker & Wagner (2015) <doi:10.1016/j.buildenv.2015.08.018> Schweiker (2022) <doi:10.1111/ina.13018>

See Also

see also [calcComfInd](#), [link{calcATHBpts}](#), [link{calcATHBset}](#),
[link{calcATHBpmv2015}](#)

Examples

```
calcATHBstandard(20, 25, 25, .1, 50, 1.1)
```

calcATHBx *PMV based on Adaptive Thermal Heat Balance Framework for the extended Model*

Description

calcATHBx calculates the PMV based on adaptive thermal heat balance framework based on the newest version (2022)

Usage

```
calcATHBx(trm, ta, tr, vel, rh, met, buildingTypeSimple,
coolingStrategyBuilding, seasonSimple)
```

Arguments

trm	- Running mean outdoor temperature in [degree C]
ta	- a numeric value presenting air temperature in [degree C]
tr	- a numeric value presenting mean radiant temperature in [degree C]
vel	- a numeric value presenting air velocity in [m/s]
rh	- a numeric value presenting relative humidity [%]
met	- a numeric value presenting metabolic rate in [met]
buildingTypeSimple	- simple building type. Value can be among Multifamily housing, Office as a string
coolingStrategyBuilding	- the process in which the building was ventilated. Value can be among Mixed Mode', 'Naturally Ventilated' as a String
seasonSimple	- season. Value can be among 'Spring', 'Summer', 'Winter' as a String

Details

aliases athb ATHB

Value

calcATHBx PMV value adapted through the ATHB approach with extended model

Author(s)

Code implemented in to R by Shaomi Rahman. Further contribution by Marcel Schweiker.

References

Schweiker & Wagner (2015) <doi:10.1016/j.buildenv.2015.08.018> Schweiker (2022) <doi:10.1111/ina.13018>

See Also

see also [calcComfInd](#), [link{calcATHBpts}](#), [link{calcATHBset}](#),
[link{calcATHBpmv2015}](#)

Examples

```
calcATHBx(20, 25, 25, .1, 50, 1.1, 'Office', 'Mixed Mode',
'winter')
```

calcAvgAcc	<i>Average Accuracy between Predicted and Actual Thermal Sensation Vote</i>
------------	---

Description

calcAvgAcc calculates the average accuracy between predicted thermal sensation votes and actual obtained sensation votes

Usage

```
calcAvgAcc(ref, pred)
```

```
calcavgacc(ref, pred)
```

```
AvgAcc(ref, pred)
```

```
avgacc(ref, pred)
```

Arguments

ref	a numeric item or vector containing categorical actual thermal sensation votes coded from -3 'cold' to +3 'hot'
pred	a numeric item or vector containing categorical predicted thermal sensation votes coded from -3 'cold' to +3 'hot'

Value

calcAvgAcc returns a single value presenting the average accuracy between actual and predicted thermal sensation votes.

Note

The outcome heavily depends on the distribution of actual votes, i.e. in case most of the actual votes are in the same category, e.g. 'neutral', the average accuracy is very high due to the fact that for the other categories the number of TRUE negative predicted votes is high as well.

Author(s)

Marcel Schweiker. Further contribution by Shoaib Sarwar.

References

Sokolova and Lapalme (2009) <doi:10.1016/j.ipm.2009.03.002>

See Also

[calcTPRTSV](#), [calcMeanBias](#)

Examples

```
## Define data
ref <- rnorm(5) # actual thermal sensation votes
ref <- cutTSV(ref)

pred <- rnorm(5) # predicted thermal sensation votes
pred <- cutTSV(pred)

calcAvgAcc(ref, pred)
```

calcBias

Bias between Predicted and Actual Thermal Sensation Vote

Description

calcMeanBias calculates the mean bias and its standard deviation and standard error between predicted thermal sensation votes and actual obtained sensation votes

Usage

```
calcBias(ref, pred)

calcBias(ref, pred)

calcMeanBias(ref, pred)

MeanBias(ref, pred)

meanBias(ref, pred)

meanBias(ref, pred)

bias(ref, pred)

calcSdBias(ref, pred)

calcSeBias(ref, pred)
```

Arguments

ref	a numeric item or vector containing categorical actual thermal sensation votes coded from -3 'cold' to +3 'hot'
pred	a numeric item or vector containing categorical predicted thermal sensation votes coded from -3 'cold' to +3 'hot'

Value

calcMeanBias returns a dataframe with the following items:

meanBias	single value presenting the mean bias between actual and predicted thermal sensation votes
sdBias	single value presenting the standard deviation of the mean bias
seBias	single value presenting the standard error of the mean bias

Author(s)

Marcel Schweiker. Further contribution by Shoaib Sarwar.

References

Humphreys & Nicol (2002) <doi:10.1016/S0378-7788(02)00018-X>

Schweiker & Wagner (2016) Exploring potentials and limitations of the adaptive thermal heat balance framework Proceedings of 9th Windsor Conference: Making Comfort Relevant Cumberland Lodge, Windsor, UK, 2016.

See Also

[calcTPRTSV](#), [calcAvgAcc](#)

Examples

```
## Define data
ref <- rnorm(5) # actual thermal sensation votes

pred <- rnorm(5) # predicted thermal sensation votes

calcBias(ref, pred)
```

calcCE	<i>Cooling Effect</i>
--------	-----------------------

Description

Function to calculate cooling effect (CE) of elevated air velocities using the standard effective temperature (SET).

Usage

```
calcCE(ta, tr, vel, rh, clo = 0.5, met = 1, wme = 0)
```

Arguments

ta	a numeric value presenting air temperature in [degree C]
tr	a numeric value presenting mean radiant temperature in [degree C]
vel	a numeric value presenting air velocity in [m/s]
rh	a numeric value presenting relative humidity [%]
clo	a numeric value presenting clothing insulation level in [clo]
met	a numeric value presenting metabolic rate in [met]
wme	a numeric value presenting external work in [met]

Details

The CE of the elevated air velocity is the difference in SET between conditions with given air velocities and still air. The cooling effect should be calculated only for air velocities higher than 0.2 m/s.

Value

ce - Cooling Effect in [degree C]

Author(s)

Code implemented in to R by Shoaib Sarwar. Further contribution by Marcel Schweiker.

References

Original code in Python by Tartarini & Schiavon (2020) <doi:10.1016/j.softx.2020.100578>

Examples

```
calcCE(25,25,0.3,50,0.5,1) # returns Cooling Effect: 1.3
```

 calcComfInd

Thermal Comfort Indices using a List of Climatic Conditions

Description

calcComfInd calculates one or more thermal comfort indices using a list of climatic conditions.

Usage

```
calcComfInd(lsCond, request = "all")
```

```
comfind(lsCond, request = "all")
```

Arguments

lsCond	a list of climatic conditions and additional variables necessary for one or more of the indices (see details below).
request	a vector with one or more comfort indices (see details below).

Details

The list lsCond could contain one or more of the following variables:

ta	Air temperature in (degree C)
tr	mean radiant temperature in (degree C)
vel	Air velocity in (m/s)
rh	Relative Humidity (%)
clo	clothing (clo)
met	metabolic rate (met)
wme	External work (met)
tu	turbulence intensity (%)
tmmo	mean monthly outdoor temperature in (degree C)
ltime	Exposure time (min)
pb	Barometric pressure (torr)
wt	weight (kg)
ht	height (cm)
trm	Running mean outdoor temperature in (degree C)
age	age (years)
gender	gender (female = 1)
tsk	mean skin temperature in (degree C)
psych	factor related to fixed effect on perceived control
apCoeff	adaptive coefficient for pmv
epCoeff	expectancy factor for pmv
asCoeff	adaptive coefficient for set
esCoeff	expectancy factor for set
asv	actual sensation vote (0 = neutral)
tao	outdoor air temperature

rho	outdoor relative humidity
frac	0.7(for seating), 0.73(for standing) [-]
eps	emissivity [-]
ic	1.084 (average permeability), 0.4 (low permeability)
tcr	initial values for core temp
tsk	initial values for skin temperature
basMet	basal metabolic rate
warmUp	length of warm up period, i.e. number of times, loop is running for HBx calculation
cdil	value for cdil in 2-node model of Gagge (applied in calculation of HbEx)
sigmatr	value for cdil in 2-node model of Gagge (applied in calculation of HbEx) In case a variable is not given, but necess

The vector request can contain the following elements:

Element	Description
"all"	Calculation of all indices described below
"pmv"	Predicted mean vote
"ppd"	Predicted percentage dissatisfied
"tnhumphreys"	Neutral temperature according to Humphreys
"tAdapt15251"	Adaptive comfort temperature according to EN 15251
"dTnz"	Distance to thermoneutral zone
"ATHBpmv"	Adaptive thermal heat balance vote based on pmv
"ATHBset"	Adaptive standard effective temperature
"ATHBpts"	Adaptive thermal heat balance vote based on set
"apmv"	Adaptive predicted mean vote according to Yao et al.
"ptsa"	Adaptive predicted thermal sensation vote according to Gao et al.
"epmv"	pmv adjusted with expectancy factor based on Fanger and toftum
"ptse"	Predicted thermal sensation vote based on set and adjusted with expectancy factor according to Gao et al.
"set"	standard effective temperature based on two node model by Gagge et al.
"et"	Effective temperature based on two node model by Gagge et al.
"tsens"	Predicted thermal sensation
"disc"	Predicted discomfort
"ps"	Predicted percentage satisfied with the level of air movement
"pd"	Predicted percentage dissatisfied due to draft
"pts"	Predicted thermal sensation vote based on set
"HBxst"	Human body exergy consumption rate using steady state method

Value

calcComfInd returns one or more rows with the comfort indices listed as request. For details see details above.

Note

In case one of the variables is not given, a standard value will be taken from a list (see [createCond](#) for details).

Author(s)

Sophia Mueller and Marcel Schweiker. Further contribution by Shaomi Rahman.

References

For references see individual functions.

See Also

see also [calcPMVPPD](#), [calc2Node](#), [calcHbExSteady](#), [calcATHBpmv2015](#), [calcdTNZ](#), [calcPMVadj](#), [calcPtsa](#), [calctAdapt](#)

Examples

```
## Creating list with all values
lsCond <- createCond()
## Requesting all comfort indices
calcComfInd(lsCond, request="all")
## Requesting a single index
calcComfInd(lsCond, request="pmv")
## Requesting multiple indices
calcComfInd(lsCond, request=c("pmv", "ptse"))
```

calcDisc

Predicted Discomfort based on the 2-Node-Model

Description

calcDisc calculates Predicted Discomfort based on the 2-Node-Model by Gagge et al.

Usage

```
calcDisc(ta, tr, vel, rh, clo = 0.5, met = 1, wme = 0, pb = 760, ltime = 60,
ht = 171, wt = 70, tu = 40, obj = "set", csw = 170, cdil = 120, cstr = 0.5)
```

Arguments

ta	a numeric value presenting air temperature in [degree C]
tr	a numeric value presenting mean radiant temperature in [degree C]
vel	a numeric value presenting air velocity in [m/s]
rh	a numeric value presenting relative humidity [%]
clo	a numeric value presenting clothing insulation level in [clo]
met	a numeric value presenting metabolic rate in [met]
wme	a numeric value presenting external work in [met]
pb	a numeric value presenting barometric pressure in [torr] or [mmHg]
ltime	a numeric value presenting exposure time in [minutes]
ht	a numeric value presenting body height in [cm]
wt	a numeric value presenting body weight in [kg]

tu	a numeric value presenting turbulence intensity in [%]
obj	a character element, either "set" or "pmvadj"
csw	a numeric value presenting the driving coefficient for regulatory sweating
cdil	a numeric value presenting the driving coefficient for vasodilation
cstr	a numeric value presenting the driving coefficient for vasoconstriction

Details

All variables must have the same length 1. For the calculation of several values use function `calcComfInd`. The value of `obj` defines whether the function will use the version presented in ASHRAE 55-2013 for adjustment of pmv (`obj = "pmvadj"`), or the original code by Gagge to calculate set (`obj = "set"`). In the version presented in ASHRAE 55-2013, the lines of code related to self-generated convection is deleted. Therefore, a difference can only be seen at higher values of met.

Value

`calcDisc` returns the Predicted Discomfort

Note

In case one of the variables is not given, a standard value will be taken from a list (see [createCond](#) for details).

Author(s)

The code for `calc2Node` is based on the code in BASIC and C++ presented by Fountain and Huizenga (1995). The translation into R-language and comparison with ASHRAE 55-2013 conducted by Marcel Schweiker.

References

ASHRAE Standard 55-2013. Thermal environmental conditions for human occupancy. American society of heating, Refrigerating and Air-Conditioning Engineering, Atlanta, USA, 2013.

Fountain & Huizenga (1995) A thermal sensation model for use by the engineering profession ASHRAE RP-781 Final report.

Gagge, Fobelets & Berglund (1986) A standard predictive index of human response to the thermal environment, ASHRAE transactions, 92 (2B), 709-731.

See Also

see also [calcComfInd](#)

Examples

```
## Using several rows of data:
ta <- c(20,22,24)
tr <- ta
vel <- rep(.15,3)
rh <- rep(50,3)

maxLength <- max(sapply(list(ta, tr, vel, rh), length))
Disc <- sapply(seq(maxLength), function(x) { calcDisc(ta[x], tr[x], vel[x], rh[x]) } )
```

calcdTNZ

dTNZ, the Distance from the Thermoneutral Zone

Description

calcdTNZ calculates the distance from the thermoneutral zone, either skin temperature or room air related.

Usage

```
calcdTNZ(ht, wt, age, gender, clo, vel, tskObs, taObs, met, rh, deltaT = .1,
fBasMet = "rosa", fSA = "duBois", percCov = 0, TcMin = 36, TcMax = 38,
plotZone = FALSE)
```

Arguments

ht	a numeric value presenting body height in [cm]
wt	a numeric value presenting body weight in [kg]
age	a numeric value presenting the age in [years]
gender	a numeric value presenting sex (female = 1, male = 2)
clo	a numeric value presenting clothing insulation level in [clo]
vel	a numeric value presenting air velocity in [m/s]
tskObs	a numeric value presenting actual mean skin temperature in [degree C]
taObs	a numeric value presenting air temperature in [degree C]
met	a numeric value presenting metabolic rate (activity related) in [met]
rh	a numeric value presenting relative humidity in [%]
deltaT	a numeric value presenting the resolution of the matrix to be used
fBasMet	a string presenting the method of calculating basal metabolic rate. Needs to be one of "rosa", "harris", "mifflin", or "fixed". Fixed will result in the value of 58.2 W/m ² .
fSA	a string presenting the method of calculating the surface area. Needs to be one of "duBois" or "mosteller".
percCov	a numeric value between 0 and 1 presenting the percentage of the body covered by clothes in [%]

TcMin	a numeric value presenting the minimum allowed core temperature in [degree C].
TcMax	a numeric value presenting the maximum allowed core temperature in [degree C].
plotZone	a boolean variable TRUE or FALSE stating, wether TNZ should be plotted or not.

Details

The percentage of the body covered by clothes can be estimated e.g. based on ISO 9920 Appendix H (Figure H.1). A typical winter case leads to a value of around .86, in the summer case this goes down to values around .68.

Value

calcdTNZ returns a dataframe with the columns dTNZ, dTNZTs, dTNZTa. Thereby
 dTNZ The absolute distance to the centroid of the thermoneutral zone
 dTNZTs Relative value of distance assuming skin temperature to be dominant for sensation
 dTNZTa Relative value of distance assuming ambient temperature to be dominant for sensation

Note

This function was used in earlier versions of TNZ calculation (see references above). The newest version is calcTNZPDF. In case one of the variables is not given, a standard value will be taken from a list (see [createCond](#) for details).

Author(s)

Marcel Schweiker and Boris Kingma

References

Kingma, Schweiker, Wagner & van Marken Lichtenbelt Exploring the potential of a biophysical model to understand thermal sensation Proceedings of 9th Windsor Conference: Making Comfort Relevant Cumberland Lodge, Windsor, UK, 2016. Kingma & van Marken Lichtenbelt (2015) <doi:10.1038/nclimate2741> Kingma, Frijns, Schellen & van Marken Lichtenbelt (2014) <doi:10.4161/temp.29702>

See Also

see also [calcTNZPDF](#) and [calcComfInd](#)

Examples

```
## Calculate all values
calcdTNZ(171, 71, 45, 1, .6, .12, 37.8, 25.3, 1.1, 50)
```

`calcepCoeff`*Coefficients for aPMV, ePMV, aPTS, ePTS*

Description

The functions `calcCOEFF` calculate the coefficients necessary for `apmv`, `epmv`, `apts`, and `epts` based on a given dataset with actual comfort votes. `calcapCoeff` calculates lambda the adaptive coefficients for `apmv`, `calcepCoeff` calculates e the expectancy factor for `epmv`, `calcasCoeff` calculates lambda the adaptive coefficients for `apts`, `calcesCoeff` calculates e the expectancy factor for `epts`.

Usage`calcapCoeff(lsCond)``calcepCoeff(lsCond)``calcasCoeff(lsCond)``calcesCoeff(lsCond)`**Arguments**

`lsCond` a list with vectors for the necessary variables (see details) .

Value

`calcCOEFF` returns the adaptive coefficient lambda or expectancy factor depending on its call.

Note

For `calcapCoeff` and `calcepCoeff`, `lsCond` should contain the following variables: `ta`, `tr`, `vel`, `rh`, `clo`, `met`, `wme`, `asv` (see [createCond](#) for details). In case one or more of these variables are not included in the list, standard values will be used.

For `calcasCoeff` and `calcesCoeff`, `lsCond` should contain the following variables: `ta`, `tr`, `vel`, `rh`, `clo`, `met`, `wme`, `pb`, `ltime`, `ht`, `wt`, `asv` (see [createCond](#) for details). In case one or more of these variables are not included in the list, standard values will be used.

Author(s)

Marcel Schweiker.

References

Coefficients are calculated based on Gao, J.; Wang, Y. and Wargocki, P. Comparative analysis of modified PMV models and set models to predict human thermal sensation in naturally ventilated buildings *Building and Environment*, 2015, 92, 200-208.

The aPMV concept was introduced by Yao, Li & Liu (2009) <doi:10.1016/j.buildenv.2009.02.014>

The epmv concept was introduced by Fanger & Toftum (2002) <doi:10.1016/S0378-7788(02)00003-8>

See Also

see also [calcaPMV](#), [calcePMV](#), [calcPtsa](#), [calcPtse](#)

Examples

```
## Note. Due to random generated asv values. The values for the coefficients will not be meaningful.
## Create sample data
ta <- 20:24      # vector with air temperature values
tr <- ta        # vector with radiant temperature values
vel <- rep(.1,5) # vector with air velocities
rh <- rep(50,5) # vector with relative humidity values
clo <- rep(1.0,5) # vector with clo values
met <- rep(1.1,5) # vector with metabolic rates
asv <- rnorm(5)  # vector with actual sensation votes

lsCond <- as.list(data.frame(ta, tr, vel, rh, clo, met, asv))

## Calculate coefficients

calcapCoeff(lsCond)
calcepCoeff(lsCond)
calcasCoeff(lsCond)
calcesCoeff(lsCond)

## use coefficients to calculate apmv
lsCond$apCoeff[1] <- calcapCoeff(lsCond)$apCoeff
calcComfInd(lsCond, request="apmv")
```

calcePMV

Adjusted Predicted Mean Votes with Expectancy Factor

Description

Function to calculate Predicted Mean Votes (PMV) adjusted by the expectancy factor.

Usage

```
calcePMV(ta, tr, vel, rh, clo = 0.5, met = 1, wme = 0, epCoeff)
```

```
ePMV(ta, tr, vel, rh, clo = 0.5, met = 1, wme = 0, epCoeff)
```

```
epmv(ta, tr, vel, rh, clo = 0.5, met = 1, wme = 0, epCoeff)
```

Arguments

ta	a numeric value presenting air temperature in [degree C]
tr	a numeric value presenting mean radiant temperature in [degree C]
vel	a numeric value presenting air velocity in [m/s]
rh	a numeric value presenting relative humidity [%]
clo	a numeric value presenting clothing insulation level in [clo]
met	a numeric value presenting metabolic rate in [met]
wme	a numeric value presenting external work in [met]
epCoeff	expectancy factor e

Details

epCoeff can be derived using calcepCoeff.

calcePMV requires the actual sensation vote related to the physical data as it is required to alter the metabolic rate.

Value

calcePMV returns the predicted mean vote adjusted by the expectancy factor.

Note

In case one of epCoeff is not given, a standard value will be taken from a list (see [createCond](#) for details).

Author(s)

Code implemented in to R by Marcel Schweiker. Further contribution by Sophia Mueller and Shoaib Sarwar.

References

epmv is based on Fanger & Toftum (2002) <doi:10.1016/S0378-7788(02)00003-8>

See Also

[calcComfInd](#), [calcepCoeff](#)

Examples

```
## Note. Due to random generated asv values. The values for the coefficients will not be meaningful.
## Create sample data
ta <- 20:24 # vector with air temperature values
tr <- ta # vector with radiant temperature values
vel <- rep(.1,5) # vector with air velocities
rh <- rep(50,5) # vector with relative humidity values
clo <- rep(1.0,5) # vector with clo values
met <- rep(1.1,5) # vector with metabolic rates
```

```

asv <- rnorm(5) # vector with actual sensation votes
lsCond <- as.list(data.frame(ta,tr,vel,rh,clo,met,asv))
## Calculate coefficient epCoeff for data set
epCoeff <- calcepCoeff(lsCond)
## calculate epmv
epmv <- NULL
for (i in 1:length(ta)){
  epmv[i] <- calcePMV(ta[i], tr[i], vel[i], rh[i], clo[i], met[i], epCoeff = epCoeff)$epmv}
epmv

```

calcET

Effective Temperature based on the 2-Node-Model

Description

calcET calculates Effective temperature based on the 2-Node-Model by Gagge et al.

Usage

```
calcET(ta, tr, vel, rh, clo = 0.5, met = 1, wme = 0, pb = 760, ltime = 60,
ht = 171,wt = 70, tu = 40, obj = "set", csw = 170, cdil = 120, cstr = 0.5)
```

Arguments

ta	a numeric value presenting air temperature in [degree C]
tr	a numeric value presenting mean radiant temperature in [degree C]
vel	a numeric value presenting air velocity in [m/s]
rh	a numeric value presenting relative humidity [%]
clo	a numeric value presenting clothing insulation level in [clo]
met	a numeric value presenting metabolic rate in [met]
wme	a numeric value presenting external work in [met]
pb	a numeric value presenting barometric pressure in [torr] or [mmHg]
ltime	a numeric value presenting exposure time in [minutes]
ht	a numeric value presenting body height in [cm]
wt	a numeric value presenting body weight in [kg]
tu	a numeric value presenting turbulence intensity in [%]
obj	a character element, either "set" or "pmvadj"
csw	a numeric value presenting the driving coefficient for regulatory sweating
cdil	a numeric value presenting the driving coefficient for vasodilation
cstr	a numeric value presenting the driving coefficient for vasoconstriction

Details

All variables must have the same length 1. For the calculation of several values use function `calcComfInd`. The value of `obj` defines whether the function will use the version presented in ASHRAE 55-2013 for adjustment of pmv (`obj = "pmvadj"`), or the original code by Gagge to calculate set (`obj = "set"`). In the version presented in ASHRAE 55-2013, the lines of code related to self-generated convection is deleted. Therefore, a difference can only be seen at higher values of `met`.

Value

`calcET` returns the Effective temperature

Note

In case one of the variables is not given, a standard value will be taken from a list (see [createCond](#) for details).

Author(s)

The code for `calc2Node` is based on the code in BASIC and C++ presented by Fountain and Huizenga (1995). The translation into R-language and comparison with ASHRAE 55-2013 conducted by Marcel Schweiker.

References

ASHRAE Standard 55-2013. Thermal environmental conditions for human occupancy. American society of heating, Refrigerating and Air-Conditioning Engineering, Atlanta, USA, 2013.

Fountain & Huizenga (1995) A thermal sensation model for use by the engineering profession ASHRAE RP-781 Final report.

Gagge, Fobelets & Berglund (1986) A standard predictive index of human response to the thermal environment, ASHRAE transactions, 92 (2B), 709-731.

See Also

see also [calcComfInd](#)

Examples

```
## Using several rows of data:
ta <- c(20,22,24)
tr <- ta
vel <- rep(.15,3)
rh <- rep(50,3)

maxLength <- max(sapply(list(ta, tr, vel, rh), length))
ET <- sapply(seq(maxLength), function(x) { calcET(ta[x], tr[x], vel[x], rh[x]) } )
```

 calcHbExSteady

Human Body Exergy Consumption Rate Using Steady State Method

Description

calcHbExSteady calculates the human body exergy consumption rate in W/m² using steady state method based on a set of environmental variables.

Usage

```
calcHbExSteady(ta, tr, rh, vel, clo, met, tao, rho, frad = 0.7, eps = 0.95,
ic = 1.085, ht = 171, wt = 70, tcr = 37, tsk = 36, basMet = 58.2, warmUp = 60,
cdil = 100, sigmatr = 0.25)
```

Arguments

ta	a numeric value presenting air temperature in [degree C]
tr	a numeric value presenting mean radiant temperature in [degree C]
rh	a numeric value presenting relative humidity [%]
vel	a numeric value presenting air velocity in [m/s]
clo	a numeric value presenting clothing insulation level in [clo]
met	a numeric value presenting metabolic rate in [met]
tao	a numeric value presenting outdoor air temperature in [degree C]
rho	a numeric value presenting outdoor relative humidity [%]
frad	a numeric value presenting the fraction of body exposed to radiation 0.7(for seating), 0.73(for standing) [-]
eps	a numeric value presenting emissivity [-]
ic	a numeric value presenting permeability of clothing: 1.084 (average permeability), 0.4 (low permeability)
ht	a numeric value presenting body height in [cm]
wt	a numeric value presenting body weight in [kg]
tcr	a numeric value presenting initial value for core temperature in [degree C]
tsk	a numeric value presenting initial value for skin temperature in [degree C]
basMet	a numeric value presenting basal metabolic rate in [met]
warmUp	a numeric value presenting length of warm up period, i.e. number of times, loop is running for HBx calculation
cdil	a numeric value presenting value for cdil in 2-node model of Gagge
sigmatr	a numeric value presenting value for cdil in 2-node model of Gagge

Value

Returns a data.frame with the following columns

Exergy input

xInmets Exergy input through metabolism [W/m2]
 xInmetwcs Label warm/ cold for exergy input through metabolism [W/m2]
 xInAIRwcs Exergy input through inhaled humid air [W/m2]
 xInAIRwcwcs Label warm/ cold for exergy input through inhaled humid air [W/m2]
 xInAIRwds Exergy input through inhaled dry air [W/m2]
 xInAIRwdwds Label wet/ dry for exergy input through inhaled dry air [W/m2]
 xInLUNGwcs Exergy input through water lung [W/m2]
 xInLUNGwcwcs Label warm/ cold for exergy input through water lung [W/m2]
 xInLUNGwds Exergy input through water lung [W/m2]
 xInLUNGwdwds Label wet/ dry for exergy input through water lung [W/m2]
 xInshelLwcs Exergy input through water from sweat [W/m2]
 xInshelLwcwcs Label warm/ cold for exergy input through water from sweat [W/m2]
 xInshelLwds Exergy input through water from sweat [W/m2]
 xInshelLwdwds Label wet/ dry for exergy input through water from sweat [W/m2]
 xInraDs Exergy input through radiation [W/m2]
 xInraDwcs Label warm/ cold for exergy input through radiation [W/m2]
 xIntotalS total exergy input [W/m2]

Exergy output

xoutstorecores Exergy stored in core [W/m2]
 xoutstoreshels Exergy stored in shell [W/m2]
 xoutaIRwcs Exergy output through exhaled humid air [W/m2]
 xoutaIRwcwcs Label warm/ cold for exergy output through exhaled humid air [W/m2]
 xoutaIRwds Exergy output through exhaled dry air [W/m2]
 xoutaIRwdwds Label wet/ dry for exergy output through exhaled dry air [W/m2]
 xoutswEATwcs Exergy output through water vapour from sweat [W/m2]
 xoutswEATwcwcs Label warm/ cold for exergy output through water vapour from sweat [W/m2]
 xoutswEATwds Exergy output through water vapour from sweat [W/m2]
 xoutswEATwdwds Label wet/ dry for exergy output through water vapour from sweat [W/m2]
 xoutraDs Exergy output through radiation [W/m2]
 xoutraDwcs Label warm/ cold for exergy output through radiation [W/m2]
 xoutCONVs Exergy output through convection [W/m2]
 xoutCONVwcs Label warm/ cold for exergy output through convection [W/m2]
 xouttotalS total exergy output [W/m2]

Exergy balance

xconss total exergy consumption [W/m2]
 xConsumption total exergy consumption [W/m2]

Additional values

tsks Calculated skin temperature [degree C]
 tcrcs Calculated core temperature [degree C]
 ws Calculated skin wettedness [degree C]

Note

According to Gagge's paper (1973), the value of 'cdil' may vary between 75 and 225 and 'sigma-tr' between 0.25 and 0.75. There is a note in the appendix of his paper saying two things: 1) whatever the values taken for cdil and sigma-tr, there must be no significant change in resulting thermal equilibrium. But, the values taken for cdil and sigmaTr do affect time to equilibrium. According to the analysis of Schweiker et al. (2016), the values of 100 and .25 lead to the best fit of calculated and observed skin temperature.

Author(s)

This function is based on a VBA code developed by Masanori Shukuya. transformation of VBA-code and Excel procedures into R syntax by Marcel Schweiker.

References

Schweiker, Kolarik, Dovjak & Shukuya (2016) <doi:10.1016/j.enbuild.2016.01.002>
 Shukuya (2015) Calculation of human body-core and skin-layer temperatures under unsteady-state conditions-for unsteady-state human-body exergy analysis-, internal report of exergy-research group, Tech. rep.

See Also

see also [calcComfInd](#), [calcHbExUnsteady](#)

Examples

```
## Calculation of human body exergy consumption rate
calcHbExSteady(22, 24, 50, .1, .8, 1.2, 5, 80)

## Calculation of multiple values
dfData <- data.frame(ta=c(20:25), tr=c(20:25))
dfResult <- calcHbExSteady(22, 24, 50, .1, .8, 1.2, 5, 80)
for(i in 1:nrow(dfData)){
dfResult[i,] <- calcHbExSteady(dfData$ta[i], dfData$tr[i], 50, .1, .5, 1.1, 5, 80)
}
```

calcHbExUnsteady

Human Body Exergy Consumption Rate using Unsteady State Method

Description

calcHbExUnsteady Function calculates the human body exergy consumption rate using unsteady state method based on a series of environmental variables.

Usage

```
calcHbExUnsteady(ta, tr, rh, vel, clo, met, tao, rho, frad = 0.7,
eps = 0.95, ic = 1.085, ht = 171, wt = 70, tcr = 37, tsk = 36, basMet = 58.2,
warmUp = 60, cdil = 100, sigmatr = 0.25, dateTime)
```

Arguments

ta	a numeric value presenting air temperature in [degree C]
tr	a numeric value presenting mean radiant temperature in [degree C]
rh	a numeric value presenting relative humidity [%]
vel	a numeric value presenting air velocity in [m/s]
clo	a numeric value presenting clothing insulation level in [clo]
met	a numeric value presenting metabolic rate in [met]
tao	a numeric vector presenting outdoor air temperature in [degree C]
rho	numeric vector presenting outdoor relative humidity [%]
frac	a numeric vector presenting the fraction of body exposed to radiation 0.7(for seating), 0.73(for standing) [-]
eps	a numeric vector presenting emissivity [-]
ic	a numeric vector presenting permeability of clothing: 1.084 (average permeability), 0.4 (low permeability)
ht	a numeric vector presenting body height in [cm]
wt	a numeric vector presenting body weight in [kg]
tcr	a numeric vector presenting initial value for core temperature in [degree C]
tsk	a numeric vector presenting initial value for skin temperature in [degree C]
basMet	a numeric vector presenting basal metabolic rate in [met]
warmUp	a numeric vector presenting length of warm up period, i.e. number of times, loop is running for HBx calculation.
cdil	a numeric vector presenting value for cdil in 2-node model of Gagge
sigmatr	a numeric vector presenting value for cdil in 2-node model of Gagge.
dateTime	a POsIxct vector of the times of measurement.

Details

This function requires vectors of data including the corresponding time stamp. In case the time between two measurements is more than a minute, intermediate values are interpolated.

Value

Returns a data.frame with the following columns. Exergy input

xInmetu	Exergy input through metabolism
xInmetwcu	Label warm/ cold for exergy input through metabolism
xInAIRwcu	Exergy input through inhaled humid air
xInAIRwcu	Label warm/ cold for exergy input through inhaled humid air
xInAIRwdu	Exergy input through inhaled dry air
xInAIRwdwdu	Label wet/ dry for exergy input through inhaled dry air
xInLUNGwcu	Exergy input through water lung

xInLUNGwcu	Label warm/ cold for exergy input through water lung
xInLUNGwdu	Exergy input through water lung
xInLUNGwdwdu	Label wet/ dry for exergy input through water lung
xInsheLLwcu	Exergy input through water from sweat
xInsheLLwcu	Label warm/ cold for exergy input through water from sweat
xInsheLLwdu	Exergy input through water from sweat
xInsheLLwdwdu	Label wet/ dry for exergy input through water from sweat
xInraDu	Exergy input through radiation
xInraDwcu	Label warm/ cold for exergy input through radiation
xIntotaLu	total exergy input
Exergy output	
xoutstorecoreu	Exergy stored in core
xoutstoreshelu	Exergy stored in shell
xoutaIRwcu	Exergy output through exhaled humid air
xoutaIRwcu	Label warm/ cold for exergy output through exhaled humid air
xoutaIRwdu	Exergy output through exhaled dry air
xoutaIRwdwdu	Label wet/ dry for exergy output through exhaled dry air
xoutswEATwcu	Exergy output through water vapour from sweat
xoutswEATwcu	Label warm/ cold for exergy output through water vapour from sweat
xoutswEATwdu	Exergy output through water vapour from sweat
xoutswEATwdwdu	Label wet/ dry for exergy output through water vapour from sweat
xoutraDu	Exergy output through radiation
xoutraDwcu	Label warm/ cold for exergy output through radiation
xoutCONVu	Exergy output through convection
xoutCONVwcu	Label warm/ cold for exergy output through convection
xouttotaLu	total exergy output
Exergy balance	
xconsu	total exergy consumPtion
Additional values	
tsku	Calculated skin temperature
tcru	Calculated core temperature
wu	Calculated skin wettedness

Note

According to Gagge's paper (1973), the value of 'cdil' may vary between 75 and 225 and 'sigma-tr' between 0.25 and 0.75. There is a note in the appendix of his paper saying two things: 1) whatever the values taken for cdil and sigma-tr, there must be no significant change in resulting thermal equilibrium. But, the values taken for cdil and sigmaTr do affect time to equilibrium. According to the analysis of schweiker et al. (2015), the values of 100 and .25 lead to the best fit of calculated and observed skin temperature.

Author(s)

This function is based on a VBA code developed by masanori Shukuya. transformation of VBA-code and Excel procedures into R syntax by Marcel Schweiker.

References

Schweiker, Kolarik, Dovjak & Shukuya (2016) <doi:10.1016/j.enbuild.2016.01.002>

Shukuya (2015) Calculation of human body-core and skin-layer temperatures under unsteady-state conditions-for unsteady-state human-body exergy analysis-, internal report of exergy-research group, Tech. rep.

See Also

see also [calcComfInd](#)

Examples

```
## Define environmental parameters
ta <- seq(20,25,.1)
tr <- ta
rh <- rep(50, length(ta))
vel <- rep(.1, length(ta))
clo <- rep(.8, length(ta))
met <- rep(1.2, length(ta))
tao <- rep(5, length(ta))
rho <- rep(80, length(ta))
dateTime <- as.POSIXct(seq(0,by=60,length.out=length(ta)), origin="1970-01-01")
## Calculation of human body exergy consumption rate
calcHbExUnsteady(ta, tr, rh, vel, clo, met, tao, rho, dateTime = dateTime)$xconsu
```

calcIREQ

IREQ and Dlim

Description

Calculate minimal and neutral values of REQUIRED CLOTHING INSULATION (IREQ) and DURATION LIMITED EXPOSURE (Dlim).

Usage

```
calcIREQ(M,W,ta,tr,p,w,v,rh,clo)
```

Arguments

M	a numeric value presenting metabolic energy production (58 to 400 W/m ²) in [W/m ²]
W	a numeric value presenting Rate of mechanical work, (normally 0) in [W/m ²]
ta	a numeric value presenting ambient air temperature in [degree C]
tr	a numeric value presenting mean radiant temperature in [degree C]
p	a numeric value presenting air permeability (low < 5, medium 50, high > 100 l/m ² s) in [l/m ² s]
w	a numeric value presenting walking speed (or calculated work created air movements) in [m/s]
v	a numeric value presenting relative air velocity(0.4 to 18 m/s) in [m/s]
rh	a numeric value presenting relative humidity [%]
clo	a numeric value presenting clothing insulation level in [clo]

Details

The function gives IREQ Insulation of clothing required to maintain thermal equilibrium of the body at specified levels of physiological stress.

Value

calcIREQ returns

IREQminimal	Lower bound of insulation required in [clo]
IREQneutral	Upper bound of insulation required in [clo]
ICLminimal	Lower bound of REQUIRED basic clothing insulation (ISO 9920) in [clo]
ICLneutral	Upper bound of REQUIRED basic clothing insulation (ISO 9920) in [clo]
DLEminimal	Lower bound of duration limited exposure in [hours]
DLEneutral	upper bound of duration limited exposure in [hours]

Note

The authors disclaim all obligations and liabilities for damages arising from the use or attempted use of the information, including, but not limited to, direct, indirect, special and consequential damages, and attorneys' and experts' fees and court costs. Any use of the information will be at the risk of the user.

Author(s)

Developed by Ingvar Holmer and Hakan O. Nilsson, 1990 in java and transferred to R by Shoab Sarwar. Further contribution by Marcel Schweiker.

References

ISO 11079, 2007-12-15, ERGONOMICS OF THE THERMAL ENVIRONMENT - DETERMINATION AND INTERPRETATION OF COLD STRESS WHEN USING REQUIRED CLOTHING INSULATION (IREQ) AND LOCAL COOLING EFFECTS

Examples

```
calcIREQ(116,0,-15,-15,8,0.3,0.4,85,2.5)
```

calcIso7933

Heat Strain Indices based on ISO 7933

Description

calcISO7933 calculates Tre, SWtotg, Dlimtre, Dlimloss50 and Dlimloss95 based on ISO 7933. It additionally provides intermediate results from the calculation: Cres, Eres, Ep, SWp, Texp, Tskeq, Tsk, wp

Usage

```
calcIso7933(accl, posture, Ta, Pa, Tr, Va, Met, Icl, THETA, Walksp, Duration,
weight, height, DRINK, Adu, spHeat, SWp, Tre, Tcr, Tsk, Tcreq, Work, imst,
Ap, Fr, defspeed, defdir, HR, pb)
```

Arguments

accl	a numeric value presenting state of acclimation [100 if acclimatised subject, 0 otherwise]
posture	a numeric value presenting posture of person [sitting=1, standing=2, crouching=3]
Ta	a numeric value presenting air temperature in [degrees celsius]
Pa	a numeric value presenting partial water vapour pressure [kPa]
Tr	a numeric value presenting mean radiant temperature in [degrees celsius]
Va	a numeric value presenting air velocity in [m/s]
Met	a numeric value presenting metabolic rate in [W/(m*m)]
Icl	a numeric value presenting static thermal insulation of clothing [clo]
THETA	a numeric value presenting angle between walking direction and wind direction in [degrees]
Walksp	a numeric value presenting walking speed in [m/s]
Duration	a numeric value presenting the duration of the work sequence in [min]
weight	a numeric value presenting the body mass in [kg]
height	a numeric value presenting the body height in [m]

DRINK	a numeric value presenting if workers can drink as they want [1 if they can drink without restriction, 0 if restricted]
Adu	a numeric value presenting body surface area according to Du Bois [m^2]
spHeat	a numeric value presenting specific body heat [$(W/(m^2))/K$]
SWp	a numeric value presenting predicted sweat rate [$W/(m^2)$]
Tre	a numeric value presenting rectal temperature [degrees celsius]
Tcr	a numeric value presenting temperature of body core [degrees celsius]
Tsk	a numeric value presenting skin temperature at start [degrees celsius]
Tcreq	a numeric value presenting temperature of body core dependent on energy metabolism [degrees celsius]
Work	a numeric value presenting effective mechanical power [$W/(m^2)$]
imst	a numeric value presenting static moisture permeability index [-]
Ap	a numeric value presenting fraction of the body surface covered by the reflective clothing [-]
Fr	a numeric value presenting emissivity of the reflective clothing [-]
defspeed	a numeric value presenting if walking speed entered [1 if walking speed entered, 0 otherwise]
defdir	a numeric value presenting if walking direction entered [1 if walking direction entered, 0 otherwise]
HR	a numeric value presenting humidity ratio [g/kg]
pb	a numeric value presenting normal barometric pressure in [Pa]

Details

All variables must have the same length 1.

Value

calcISO7933 returns a data.frame with the following items:

Tre final rectal temperature [degrees Celsius]

SWtotg total water loss [g]

Dlimtre time when limit for rectal temperature is reached [min]

Dlimloss50 time when limit for water loss Dmax50 (7.5 percent of body mass of an average person) is reached [min]

Dlimloss95 time when limit for water loss Dmax95 (5 percent of body mass of 95 percent of the working people) is reached [min]

Cres convective heat flow at respiration [$W/(m^2)$]

Eres evaporative heat flow at respiration [W/(m*m)]

Ep predicted evaporative heat flow [W/(m*m)]

SWp predicted sweating rate [W/(m*m)]

Temp temperature of the exhaled air [degrees Celsius]

Tskeq skin Temperature in equilibrium [degrees Celsius]

Tsk skin Temperature at the minute [degrees Celsius]

wp predicted skin wettedness [-]

Note

In case one of the variables is not given, a standard value according to ISO 7933 will be taken.

Author(s)

The code for calcISO7933 is based on the code in BASIC presented in Addendum E of EN ISO 7933. The translation into R-language conducted by Michael Kleber.

References

ISO 7933 (2004) Ergonomics of the thermal environment - Analytical determination and interpretation of heat stress using calculation of the predicted heat strain Malchaire, Piette, Kampmann, Mehnert, Gebhardt, Havenith, Den Hartog, Holmer, Parsons, Alfano, Griefahn (2000) <doi:10.1016/S0003-4878(00)00030-2> Malchaire, Kampmann, Havenith, Mehnert, Gebhardt (2000) <doi:10.1007/s004200050420>

Examples

```
## Calculation of a single set of values.
calcIso7933(accl = 100, posture = 2, Ta = 35, Pa = 4, Tr = 35, Va = 0.3, Met = 150,
Icl = 0.5, THETA = 0, Walksp = 0, Duration = 480)
calcIso7933(100,2,35,4,35,0.3,150,0.5,0,0,480)
## Using several rows of data:
accl <- 100
posture <- 2
Ta <- c(40,35)
Pa <- c(2.5,4)
Tr <- c(40,35)
Va <- 0.3
Met <- 150
Icl <- 0.5
THETA <- 0
Walksp <- 0
Duration <- 480
maxLength <- max(sapply(list(accl, posture, Ta, Pa, Tr, Va, Met, Icl, THETA,
Walksp, Duration), length))
```



```
PHI <- sapply(seq(maxLength), function(x) {calcIso7933(accl, posture, Ta[x],  
Pa[x], Tr[x], Va, Met, Icl, THETA, Walksp, Duration) } )
```

calcMixR

Various Humidity Related Values

Description

This set of functions calculates different humidity related values based on the given entities.

Usage

```
calcDewp(ta, rh)  
calcEnth(ta, rh, pb)  
calcHumx(ta, rh)  
calcMixR(ta, rh, pb)  
calcRH(ta, mr, pb)  
calcSVP(ta)  
calcVP(ta, mr, pb)  
calcVapourpressure(ta, rh)
```

Arguments

ta	a numeric value or vector presenting air temperature in [degree C].
rh	a numeric value or vector presenting relative humidity in [%], except for calcVapourpressure, where it must be in decimal (e.g. 0.5).
pb	a numeric value or vector presenting barometric pressure in [torr].
mr	a numeric value or vector presenting the mixing ratio in [g/kg].

Details

The length of the arguments must be either the same or they must have the length one and one common second length.

Value

calcDewp returns the dew point temperature in [degree C]
calcEnth returns a single value or a vector of values of enthalpy in [J]
calcHumx returns a single value or a vector of values of the humidex of air []
calcMixR returns a single value or a vector of mixIng ratio in [g/kg]
calcRH returns a single value or a vector of relative humidities in [%]
calcSVP returns a single value or a vector of saturation vapor pressure in [kpa]
calcVP returns a single value or a vector of vapor pressure in [kpa]
calcVapourpressure returns a single value or a vector of vapor pressure in [kpa]

Author(s)

Michael Kleber (code and documentation), Marcel Schweiker (documentation).

References

Ranaa, Kusya, Jurdaka, Wallb & Hua (2013) <doi:10.1016/j.enbuild.2013.04.019>
Masterton & Richardson (1979) Humidex a method of quantifying human discomfort due to excessive heat and humidity, cII 1-79. Downsview, Ont: Environment Canada. Atmospheric Environment Service.

Examples

```
## Calc single value of absolute humidity
ta <- 25
rh <- 50
calcMixR(ta, rh, 760)
## Calc set of values of absolute humidity
ta <- 25:30
rh <- 50
calcMixR(ta, rh, 760)
## Calculating dew point temperature with single values for ta and rh
calcDewp(25, 50)
## Calculating dew point temperature with a vector of values for ta and a single value for rh
calcDewp(25:29, 50)
## Calc single value of enthalpy
ta <- 25
rh <- 50
calcEnth(ta, rh, 760)
## Calc set of values of enthalpy
ta <- 25:30
rh <- 50
calcEnth(ta, rh, 760)
```

`calcMRTglobe`*MRT calculation based on standard and mixed convection*

Description

`calcMRTglobe` calculates the mean radiant temperature considering mixed convection

Usage

```
calcMRTglobe(tg, ta, vel, x = 0.15)
```

Arguments

<code>tg</code>	- a numeric value presenting globe temperature in [degree C]
<code>ta</code>	- a numeric value presenting air temperature in [degree C]
<code>vel</code>	- a numeric value presenting air velocity in [m/s]
<code>x</code>	- a numeric value presenting globe diameter in [m]

Details

aliases MRT globe

This model has only been validated from $x = 0.040\text{m}$ (ping pong ball) to $x = 0.150\text{m}$ (standard globe thermometer) globes

Value

`calcMRTglobe` MRT with standard and mixed correction

Author(s)

code implemented into R by Shaomi Rahman and Marcel Schweiker.

References

Teitelbaum et al. (2022) <10.1038/s41598-022-10172-5> Teitelbaum (2022) <<https://github.com/eteitelb/MixedConvection>>

Examples

```
#Globe temperature [C]
tg <- 30
#Air temperature [C]
ta <- 24
#Air speed [m/s]
vel <- 0.0
calcMRTglobe(tg, ta, vel)
```

calcPD	<i>Predicted Percentage Dissatisfied due to Draft based on the 2-Node-Model</i>
--------	---

Description

calcPD calculates Predicted Percentage Dissatisfied due to Draft based on the 2-Node-Model by Gagge et al.

Usage

```
calcPD(ta, tr, vel, rh, clo = 0.5, met = 1, wme = 0, pb = 760, ltime = 60,
ht = 171, wt = 70, tu = 40, obj = "set", csw = 170, cdil = 120, cstr = 0.5)
```

Arguments

ta	a numeric value presenting air temperature in [degree C]
tr	a numeric value presenting mean radiant temperature in [degree C]
vel	a numeric value presenting air velocity in [m/s]
rh	a numeric value presenting relative humidity [%]
clo	a numeric value presenting clothing insulation level in [clo]
met	a numeric value presenting metabolic rate in [met]
wme	a numeric value presenting external work in [met]
pb	a numeric value presenting barometric pressure in [torr] or [mmHg]
ltime	a numeric value presenting exposure time in [minutes]
ht	a numeric value presenting body height in [cm]
wt	a numeric value presenting body weight in [kg]
tu	a numeric value presenting turbulence intensity in [%]
obj	a character element, either "set" or "pmvadj"
csw	a numeric value presenting the driving coefficient for regulatory sweating
cdil	a numeric value presenting the driving coefficient for vasodilation
cstr	a numeric value presenting the driving coefficient for vasoconstriction

Details

All variables must have the same length 1. For the calculation of several values use function calcComfInd. The value of obj defines whether the function will use the version presented in ASHRAE 55-2013 for adjustment of pmv (obj = "pmvadj"), or the original code by Gagge to calculate set (obj = "set"). In the version presented in ASHRAE 55-2013, the lines of code related to self-generated convection is deleted. Therefore, a difference can only be seen at higher values of met.

Value

calcPD returns the Predicted Percentage Dissatisfied due to Draft

Note

In case one of the variables is not given, a standard value will be taken from a list (see [createCond](#) for details).

Author(s)

The code for calc2Node is based on the code in BASIC and C++ presented by Fountain and Huizenga (1995). The translation into R-language and comparison with ASHRAE 55-2013 conducted by Marcel Schweiker.

References

ASHRAE Standard 55-2013. Thermal environmental conditions for human occupancy. American society of heating, Refrigerating and Air-Conditioning Engineering, Atlanta, USA, 2013.

Fountain & Huizenga (1995) A thermal sensation model for use by the engineering profession ASHRAE RP-781 Final report.

Gagge, Fobelets & Berglund (1986) A standard predictive index of human response to the thermal environment, ASHRAE transactions, 92 (2B), 709-731.

See Also

see also [calcComfInd](#)

Examples

```
## Using several rows of data:
ta <- c(20,22,24)
tr <- ta
vel <- rep(.15,3)
rh <- rep(50,3)

maxLength <- max(sapply(list(ta, tr, vel, rh), length))
pd <- sapply(seq(maxLength), function(x) { calcPD(ta[x], tr[x], vel[x], rh[x]) } )
```

calcPMV

Predicted Mean Votes (PMV)

Description

Function to calculate Predicted Mean Vote (PMV).

Usage

```
calcPMV(ta, tr, vel, rh, clo=.5, met=1, wme=0, basMet=58.15)
```

Arguments

ta	a numeric value presenting air temperature in [degree C]
tr	a numeric value presenting mean radiant temperature in [degree C]
vel	a numeric value presenting air velocity in [m/s]
rh	a numeric value presenting relative humidity [%]
clo	a numeric value presenting clothing insulation level in [clo]
met	a numeric value presenting metabolic rate in [met]
wme	a numeric value presenting external work in [met]
basMet	a numeric value presenting basal metabolic rate [w/m2]

Details

The PMV is an index that predicts the mean value of the thermal sensation of a large group of people on a sensation scale expressed from (-3) to (+3) corresponding to the categories cold, cool, slightly cool, neutral, slightly warm, warm and hot. PMV model is limited to air speeds below 0.20 m/s.

Note that the adjustments in the value for basMet need to be made with great cautiousness as the PMV calculation is an empirical model and might not be valid for other values of basMet than the one commonly used.

Value

PMV - Predicted Mean Vote

Author(s)

Code implemented in to R by Marcel Schweiker. Further contribution by Sophia Mueller and Shoaib Sarwar.

References

Fanger (1970) Thermal Comfort Analysis and Applications in Environmental Engineering McGraw-Hill, New York.

ISO 7730 (2005) Ergonomics of the thermal environment analytical determination and interpretation of thermal comfort using calculation of the pmv and ppd indices and local thermal comfort criteria.

Examples

```
calcPMV(25,25,0.3,50,0.5,1)
```

`calcPMVadj`*Predicted Mean Votes adjusted for elevated air speed*

Description

Function to calculate Predicted Mean Votes (PMV) adjusted for cooling effect of elevated air speed.

Usage

```
calcPMVadj(ta, tr, vel, rh, clo, met, wme = 0)
```

Arguments

<code>ta</code>	a numeric value presenting air temperature in [degree C]
<code>tr</code>	a numeric value presenting mean radiant temperature in [degree C]
<code>vel</code>	a numeric value presenting air velocity in [m/s]
<code>rh</code>	a numeric value presenting relative humidity [%]
<code>clo</code>	a numeric value presenting clothing insulation level in [clo]
<code>met</code>	a numeric value presenting metabolic rate in [met]
<code>wme</code>	a numeric value presenting external work in [met]

Details

Calculated through function `Two node model(calc2Node`

Value

`calcpmvadj` returns the predicted mean vote adjusted for the cooling effect of elevated air speed.

Author(s)

Code implemented in to R by Marcel Schweiker. Further contribution by Sophia Mueller and Shoaib Sarwar.

References

`pmvadj` is based on ASHRAE standard 55-2013. Thermal environmental conditions for human occupancy. American society of heating, Refrigerating and Air-Conditioning Engineering, Atlanta, USA, 2013.

Examples

```
calcPMVadj(25,25,0.3,50,0.5,1)
```

 calcPMVGagge

Gagge's Version of Fanger's PMV based on the 2-Node-Model

Description

calcPMVGagge calculates Gagge's Version of Fanger's PMV based on the 2-Node-Model by Gagge et al.

Usage

```
calcPMVGagge(ta, tr, vel, rh, clo = 0.5, met = 1, wme = 0, pb = 760,
ltime = 60, ht = 171, wt = 70, tu = 40, obj = "set", csw = 170, cdil = 120,
cstr = 0.5)
```

Arguments

ta	a numeric value presenting air temperature in [degree C]
tr	a numeric value presenting mean radiant temperature in [degree C]
vel	a numeric value presenting air velocity in [m/s]
rh	a numeric value presenting relative humidity [%]
clo	a numeric value presenting clothing insulation level in [clo]
met	a numeric value presenting metabolic rate in [met]
wme	a numeric value presenting external work in [met]
pb	a numeric value presenting barometric pressure in [torr] or [mmHg]
ltime	a numeric value presenting exposure time in [minutes]
ht	a numeric value presenting body height in [cm]
wt	a numeric value presenting body weight in [kg]
tu	a numeric value presenting turbulence intensity in [%]
obj	a character element, either "set" or "pmvadj"
csw	a numeric value presenting the driving coefficient for regulatory sweating
cdil	a numeric value presenting the driving coefficient for vasodilation
cstr	a numeric value presenting the driving coefficient for vasoconstriction

Details

All variables must have the same length 1. For the calculation of several values use function calcComfInd. The value of obj defines whether the function will use the version presented in ASHRAE 55-2013 for adjustment of pmv (obj = "pmvadj"), or the original code by Gagge to calculate set (obj = "set"). In the version presented in ASHRAE 55-2013, the lines of code related to self-generated convection is deleted. Therefore, a difference can only be seen at higher values of met.

Value

calcPMVGagge returns Gagge's Version of Fanger's PMV

Note

In case one of the variables is not given, a standard value will be taken from a list (see [createCond](#) for details).

Author(s)

The code for calc2Node is based on the code in BASIC and C++ presented by Fountain and Huizenga (1995). The translation into R-language and comparison with ASHRAE 55-2013 conducted by Marcel Schweiker.

References

ASHRAE Standard 55-2013. Thermal environmental conditions for human occupancy. American society of heating, Refrigerating and Air-Conditioning Engineering, Atlanta, USA, 2013.

Fountain & Huizenga (1995) A thermal sensation model for use by the engineering profession ASHRAE RP-781 Final report.

Gagge, Fobelets & Berglund (1986) A standard predictive index of human response to the thermal environment, ASHRAE transactions, 92 (2B), 709-731.

See Also

see also [calcComfInd](#)

Examples

```
## Using several rows of data:
ta <- c(20,22,24)
tr <- ta
vel <- rep(.15,3)
rh <- rep(50,3)

maxLength <- max(sapply(list(ta, tr, vel, rh), length))
pmvg <- sapply(seq(maxLength), function(x) { calcPMVGagge(ta[x], tr[x], vel[x], rh[x]) })
```

calcPMVPPD

PMV and PPD

Description

Function to calculate Predicted Mean Vote (PMV) and Predicted Percentage of Dissatisfied (PPD).

Usage

```
calcPMVPPD(ta, tr, vel, rh, clo=.5, met=1, wme=0, basMet=58.15, getLoad = FALSE)
```

Arguments

ta	a numeric value presenting air temperature in [degree C]
tr	a numeric value presenting mean radiant temperature in [degree C]
vel	a numeric value presenting air velocity in [m/s]
rh	a numeric value presenting relative humidity [%]
clo	a numeric value presenting clothing insulation level in [clo]
met	a numeric value presenting metabolic rate in [met]
wme	a numeric value presenting external work in [met]
basMet	a numeric value presenting basal metabolic rate [w/m2]
getLoad	a boolean value. Set to true to get thermal load as output instead of PMV/PPD

Details

The PMV is an index that predicts the mean value of the thermal sensation of a large group of people on a sensation scale expressed from (-3) to (+3) corresponding to the categories cold, cool, slightly cool, neutral, slightly warm, warm and hot. The PPD is an index that establishes a quantitative prediction of the percentage of thermally dissatisfied people determined from PMV.

Note that the adjustments in the value for basMet need to be made with great cautiousness as the PMV calculation is an empirical model and might not be valid for other values of basMet than the one commonly used.

Value

PMV - Predicted Mean Vote

PPD - Predicted Percentage of Dissatisfied occupants in [%]

Lraw - thermal load (only when getLoad was set to TRUE)

Author(s)

Code implemented in to R by Marcel Schweiker. Further contribution by Sophia Mueller and Shoaib Sarwar.

References

Fanger (1970) Thermal Comfort Analysis and Applications in Environmental Engineering McGraw-Hill, New York.

ISO 7730 Ergonomics of the thermal environment analytical determination and interpretation of thermal comfort using calculation of the pmv and ppd indices and local thermal comfort criteria 2005.

See Also

see also [calcComfInd](#)

Examples

```
calcPMVPPD(25,25,0.3,50,0.5,1)
```

 calcPMVStar

Fanger's PMV using SET for DRY*

Description

calcPMVStar calculates Fanger's PMV based on the 2-Node-Model by Gagge et al. except that DRY is calculated using SET* rather than the operative temperature

Usage

```
calcPMVStar(ta, tr, vel, rh, clo = 0.5, met = 1, wme = 0, pb = 760,
ltime = 60, ht = 171, wt = 70, tu = 40, obj = "set", csw = 170, cdil = 120,
cstr = 0.5)
```

Arguments

ta	a numeric value presenting air temperature in [degree C]
tr	a numeric value presenting mean radiant temperature in [degree C]
vel	a numeric value presenting air velocity in [m/s]
rh	a numeric value presenting relative humidity [%]
clo	a numeric value presenting clothing insulation level in [clo]
met	a numeric value presenting metabolic rate in [met]
wme	a numeric value presenting external work in [met]
pb	a numeric value presenting barometric pressure in [torr] or [mmHg]
ltime	a numeric value presenting exposure time in [minutes]
ht	a numeric value presenting body height in [cm]
wt	a numeric value presenting body weight in [kg]
tu	a numeric value presenting turbulence intensity in [%]
obj	a character element, either "set" or "pmvadj"
csw	a numeric value presenting the driving coefficient for regulatory sweating
cdil	a numeric value presenting the driving coefficient for vasodilation
cstr	a numeric value presenting the driving coefficient for vasoconstriction

Details

All variables must have the same length 1. For the calculation of several values use function calcComfInd. The value of obj defines whether the function will use the version presented in ASHRAE 55-2013 for adjustment of pmv (obj = "pmvadj"), or the original code by Gagge to calculate set (obj = "set"). In the version presented in ASHRAE 55-2013, the lines of code related to self-generated convection is deleted. Therefore, a difference can only be seen at higher values of met.

Value

calcPMVStar returns Fanger's PMV except that DRY is calculated using SET* rather than the operative temperature

Note

In case one of the variables is not given, a standard value will be taken from a list (see [createCond](#) for details).

Author(s)

The code for calc2Node is based on the code in BASIC and C++ presented by Fountain and Huizenga (1995). The translation into R-language and comparison with ASHRAE 55-2013 conducted by Marcel Schweiker.

References

ASHRAE Standard 55-2013. Thermal environmental conditions for human occupancy. American society of heating, Refrigerating and Air-Conditioning Engineering, Atlanta, USA, 2013.

Fountain & Huizenga (1995) A thermal sensation model for use by the engineering profession ASHRAE RP-781 Final report.

Gagge, Fobelets & Berglund (1986) A standard predictive index of human response to the thermal environment, ASHRAE transactions, 92 (2B), 709-731.

See Also

see also [calcComfInd](#)

Examples

```
## Using several rows of data:
ta <- c(20,22,24)
tr <- ta
vel <- rep(.15,3)
rh <- rep(50,3)

maxLength <- max(sapply(list(ta, tr, vel, rh), length))
pmvstar <- sapply(seq(maxLength), function(x) { calcPMVStar(ta[x], tr[x], vel[x], rh[x]) })
```

calcPPD

Predicted Percentage of Dissatisfied (PPD)

Description

Function to calculate Predicted Percentage of Dissatisfied (PPD).

Usage

```
calcPPD(ta, tr, vel, rh, clo=.5, met=1, wme=0, basMet=58.15)
```

Arguments

ta	a numeric value presenting air temperature in [degree C]
tr	a numeric value presenting mean radiant temperature in [degree C]
vel	a numeric value presenting air velocity in [m/s]
rh	a numeric value presenting relative humidity [%]
clo	a numeric value presenting clothing insulation level in [clo]
met	a numeric value presenting metabolic rate in [met]
wme	a numeric value presenting external work in [met]
basMet	a numeric value presenting basal metabolic rate [w/m2]

Details

The PPD is an index that establishes a quantitative prediction of the percentage of thermally dissatisfied people determined from PMV.

Note that the adjustments in the value for basMet need to be made with great cautiousness as the PMV calculation is an empirical model and might not be valid for other values of basMet than the one commonly used.

Value

PPD - Predicted Percentage of Dissatisfied occupants in [%]

Author(s)

Code implemented in to R by Marcel Schweiker. Further contribution by Sophia Mueller and Shoaib Sarwar.

References

Fanger (1970) Thermal Comfort Analysis and Applications in Environmental Engineering McGraw-Hill, New York.

ISO 7730 Ergonomics of the thermal environment analytical determination and interpretation of thermal comfort using calculation of the pmv and ppd indices and local thermal comfort criteria 2005.

Examples

```
calcPPD(25,25,0.3,50,0.5,1)
```

calcPS	<i>Predicted Percentage Satisfied with the Level of Air Movement based on the 2-Node-Model</i>
--------	--

Description

calcPS calculates Predicted Percentage Satisfied with the Level of Air Movement based on the 2-Node-Model by Gagge et al.

Usage

```
calcPS(ta, tr, vel, rh, clo = 0.5, met = 1, wme = 0, pb = 760, ltime = 60,
ht = 171, wt = 70, tu = 40, obj = "set", csw = 170, cdil = 120, cstr = 0.5)
```

Arguments

ta	a numeric value presenting air temperature in [degree C]
tr	a numeric value presenting mean radiant temperature in [degree C]
vel	a numeric value presenting air velocity in [m/s]
rh	a numeric value presenting relative humidity [%]
clo	a numeric value presenting clothing insulation level in [clo]
met	a numeric value presenting metabolic rate in [met]
wme	a numeric value presenting external work in [met]
pb	a numeric value presenting barometric pressure in [torr] or [mmHg]
ltime	a numeric value presenting exposure time in [minutes]
ht	a numeric value presenting body height in [cm]
wt	a numeric value presenting body weight in [kg]
tu	a numeric value presenting turbulence intensity in [%]
obj	a character element, either "set" or "pmvadj"
csw	a numeric value presenting the driving coefficient for regulatory sweating
cdil	a numeric value presenting the driving coefficient for vasodilation
cstr	a numeric value presenting the driving coefficient for vasoconstriction

Details

All variables must have the same length 1. For the calculation of several values use function calcComfInd. The value of obj defines whether the function will use the version presented in ASHRAE 55-2013 for adjustment of pmv (obj = "pmvadj"), or the original code by Gagge to calculate set (obj = "set"). In the version presented in ASHRAE 55-2013, the lines of code related to self-generated convection is deleted. Therefore, a difference can only be seen at higher values of met.

Value

calcPS returns the Predicted Percentage Satisfied with the Level of Air Movement

Note

In case one of the variables is not given, a standard value will be taken from a list (see [createCond](#) for details).

Author(s)

The code for calc2Node is based on the code in BASIC and C++ presented by Fountain and Huizenga (1995). The translation into R-language and comparison with ASHRAE 55-2013 conducted by Marcel Schweiker.

References

ASHRAE Standard 55-2013. Thermal environmental conditions for human occupancy. American society of heating, Refrigerating and Air-Conditioning Engineering, Atlanta, USA, 2013.

Fountain & Huizenga (1995) A thermal sensation model for use by the engineering profession ASHRAE RP-781 Final report.

Gagge, Fobelets & Berglund (1986) A standard predictive index of human response to the thermal environment, ASHRAE transactions, 92 (2B), 709-731.

See Also

see also [calcComfInd](#)

Examples

```
## Using several rows of data:
ta <- c(20,22,24)
tr <- ta
vel <- rep(.15,3)
rh <- rep(50,3)

maxLength <- max(sapply(list(ta, tr, vel, rh), length))
ps <- sapply(seq(maxLength), function(x) { calcPS(ta[x], tr[x], vel[x], rh[x]) } )
```

calcPTS

Predicted Thermal Sensation Vote based on SET

Description

calcPTS calculates Predicted Thermal Sensation Vote based on SET by the 2-Node-Model by Gagge et al.

Usage

```
calcPTS(ta, tr, vel, rh, clo = 0.5, met = 1, wme = 0, pb = 760, ltime = 60,
        ht = 171, wt = 70, tu = 40, obj = "set", csw = 170, cdil = 120, cstr = 0.5)
```

Arguments

ta	a numeric value presenting air temperature in [degree C]
tr	a numeric value presenting mean radiant temperature in [degree C]
vel	a numeric value presenting air velocity in [m/s]
rh	a numeric value presenting relative humidity [%]
clo	a numeric value presenting clothing insulation level in [clo]
met	a numeric value presenting metabolic rate in [met]
wme	a numeric value presenting external work in [met]
pb	a numeric value presenting barometric pressure in [torr] or [mmHg]
ltime	a numeric value presenting exposure time in [minutes]
ht	a numeric value presenting body height in [cm]
wt	a numeric value presenting body weight in [kg]
tu	a numeric value presenting turbulence intensity in [%]
obj	a character element, either "set" or "pmvadj"
csw	a numeric value presenting the driving coefficient for regulatory sweating
cdil	a numeric value presenting the driving coefficient for vasodilation
cstr	a numeric value presenting the driving coefficient for vasoconstriction

Details

All variables must have the same length 1. For the calculation of several values use function `calcComfInd`. The value of `obj` defines whether the function will use the version presented in ASHRAE 55-2013 for adjustment of pmv (`obj = "pmvadj"`), or the original code by Gagge to calculate set (`obj = "set"`). In the version presented in ASHRAE 55-2013, the lines of code related to self-generated convection is deleted. Therefore, a difference can only be seen at higher values of `met`.

Value

`calcPTS` returns the Predicted Thermal Sensation Vote based on SET

Note

In case one of the variables is not given, a standard value will be taken from a list (see `createCond` for details).

Author(s)

The code for `calc2Node` is based on the code in BASIC and C++ presented by Fountain and Huizenga (1995). The translation into R-language and comparison with ASHRAE 55-2013 conducted by Marcel Schweiker.

References

ASHRAE Standard 55-2013. Thermal environmental conditions for human occupancy. American society of heating, Refrigerating and Air-Conditioning Engineering, Atlanta, USA, 2013.

Fountain, M. & Huizenga, C. A thermal sensation model for use by the engineering profession ASHRAE RP-781 Final report, 1995

Gagge, A. P., Fobelets, A. P. and Berglund, L. G. A standard predictive index of human response to the thermal environment, ASHRAE transactions, 1986, 92 (2B), 709-731.

See Also

see also [calcComfInd](#)

Examples

```
## Using several rows of data:
ta <- c(20,22,24)
tr <- ta
vel <- rep(.15,3)
rh <- rep(50,3)

maxLength <- max(sapply(list(ta, tr, vel, rh), length))
pts <- sapply(seq(maxLength), function(x) { calcPTS(ta[x], tr[x], vel[x], rh[x]) } )
```

calcPtsa	<i>Predicted Thermal Sensation based on 2-Node Model adjusted for Adaptation</i>
----------	--

Description

calcPtsa calculates Predicted Thermal Sensation based on the 2-Node-Model by Gagge et al. and adjusts its output according to adaptive coefficient

Usage

```
calcPtsa(ta, tr, vel, rh, clo = .5, met = 1, wme = 0, pb = 760,
         ltime = 60, ht = 171, wt = 70, tu = 40, asCoeff)
```

Arguments

ta	a numeric value presenting air temperature in [degree C]
tr	a numeric value presenting mean radiant temperature in [degree C]
vel	a numeric value presenting air velocity in [m/s]
rh	a numeric value presenting relative humidity [%]
clo	a numeric value presenting clothing insulation level in [clo]
met	a numeric value presenting metabolic rate in [met]

wme	a numeric value presenting external work in [met]
pb	a numeric value presenting barometric pressure in [torr] or [mmHg]
ltime	a numeric value presenting exposure time in [minutes]
ht	a numeric value presenting body height in [cm]
wt	a numeric value presenting body weight in [kg]
tu	a numeric value presenting turbulence intensity in [%]
asCoeff	a numeric values presenting adaptive coefficient [-]

Details

All variables must have the same length 1. For the calculation of several values use function `calcComfInd`. The value of `obj` defines whether the function will use the version presented in ASHRAE 55-2013 for adjustment of pmv (`obj = "pmvadj"`), or the original code by Gagge to calculate set (`obj = "set"`). In the version presented in ASHRAE 55-2013, the lines of code related to self-generated convection is deleted. Therefore, a difference can only be seen at higher values of met.

Value

`calcPtsa` returns a dataframe containing the Predicted Thermal Sensation value

Note

In case one of the variables is not given, a standard value will be taken from a list (see [createCond](#) for details).

Author(s)

The code for `calc2Node` is based on the code in BASIC and C++ presented by Fountain and Huizenga (1995). The translation into R-language and comparison with ASHRAE 55-2013 conducted by Marcel Schweiker.

References

ASHRAE Standard 55-2013. Thermal environmental conditions for human occupancy. American society of heating, Refrigerating and Air-Conditioning Engineering, Atlanta, USA, 2013. Fountain & Huizenga (1995) A thermal sensation model for use by the engineering profession ASHRAE RP-781 Final report.

Gagge, Fobelets & Berglund (1986) A standard predictive index of human response to the thermal environment, ASHRAE transactions, 92 (2B), 709-731. Coefficients are calculated based on Gao, Wang & Wargocki (2015) <doi:10.1016/j.buildenv.2015.04.030> The aPMV concept was introduced by Yao, Li & Liu (2009) <doi:10.1016/j.buildenv.2009.02.014> The ePMV concept was introduced by Fanger & Toftum (2002) <doi:10.1016/S0378-7788(02)00003-8>

See Also

see also [calcComfInd](#) and [calc2Node](#)

Examples

```
## Using several rows of data:
ta <- c(20,22,24)
tr <- ta
vel <- rep(.15,3)
rh <- rep(50,3)
asCoeff <- 0.5

maxLength <- max(sapply(list(ta, tr, vel, rh,asCoeff), length))
ptsa <- sapply(seq(maxLength), function(x) { calcPtsa(ta[x], tr[x], vel[x],
rh[x], asCoeff=asCoeff) } )
```

calcPtse	<i>Predicted Thermal Sensation based on 2-Node Model adjusted for Expectancy</i>
----------	--

Description

calcPtse calculates Predicted Thermal Sensation based on the 2-Node-Model by Gagge et al. and adjusts its output according to expectancy factor

Usage

```
calcPtse(ta, tr, vel, rh, clo = .5, met = 1, wme = 0, pb = 760,
         ltime = 60, ht = 171, wt = 70, tu = 40, esCoeff)
```

Arguments

ta	a numeric value presenting air temperature in [degree C]
tr	a numeric value presenting mean radiant temperature in [degree C]
vel	a numeric value presenting air velocity in [m/s]
rh	a numeric value presenting relative humidity [%]
clo	a numeric value presenting clothing insulation level in [clo]
met	a numeric value presenting metabolic rate in [met]
wme	a numeric value presenting external work in [met]
pb	a numeric value presenting barometric pressure in [torr] or [mmHg]
ltime	a numeric value presenting exposure time in [minutes]
ht	a numeric value presenting body height in [cm]
wt	a numeric value presenting body weight in [kg]
tu	a numeric value presenting turbulence intensity in [%]
esCoeff	a numeric values presenting expectancy factor [-]

Details

All variables must have the same length 1. For the calculation of several values use function `calcComfInd`. The value of `obj` defines whether the function will use the version presented in ASHRAE 55-2013 for adjustment of pmv (`obj = "pmvadj"`), or the original code by Gagge to calculate set (`obj = "set"`). In the version presented in ASHRAE 55-2013, the lines of code related to self-generated convection is deleted. Therefore, a difference can only be seen at higher values of `met`.

Value

`calcPtse` returns a dataframe containing the Predicted Thermal Sensation value

Note

In case one of the variables is not given, a standard value will be taken from a list (see [createCond](#) for details).

Author(s)

The code for `calc2Node` is based on the code in BASIC and C++ presented by Fountain and Huizenga (1995). The translation into R-language and comparison with ASHRAE 55-2013 conducted by Marcel Schweiker.

References

ASHRAE Standard 55-2013. Thermal environmental conditions for human occupancy. American society of heating, Refrigerating and Air-Conditioning Engineering, Atlanta, USA, 2013. Fountain & Huizenga (1995) A thermal sensation model for use by the engineering profession ASHRAE RP-781 Final report.

Gagge, Fobelets & Berglund (1986) A standard predictive index of human response to the thermal environment, ASHRAE transactions, 92 (2B), 709-731. Coefficients are calculated based on Gao, Wang & Wargoeki (2015) <doi:10.1016/j.buildenv.2015.04.030> The aPMV concept was introduced by Yao, Li & Liu (2009) <doi:10.1016/j.buildenv.2009.02.014> The ePMV concept was introduced by Fanger & Toftum (2002) <doi:10.1016/S0378-7788(02)00003-8>

See Also

see also [calcComfInd](#) and [calc2Node](#)

Examples

```
## Using several rows of data:
ta <- c(20,22,24)
tr <- ta
vel <- rep(.15,3)
rh <- rep(50,3)
esCoeff <- 0.5

maxLength <- max(sapply(list(ta, tr, vel, rh), length))
ptse <- sapply(seq(maxLength), function(x) { calcPtse(ta[x], tr[x], vel[x],
```

```
rh[x], esCoeff=esCoeff) } )
```

 calcRT

Required recovery time

Description

Function to calculate Required recovery time, RT in hours.

Usage

```
calcRT(M,W,ta,tr,p,w,v,rh,clo)
```

Arguments

M	a numeric value presenting metabolic energy production (58 to 400 W/m ²) in [W/m ²]
W	a numeric value presenting Rate of mechanical work, (normally 0) in [W/m ²]
ta	a numeric value presenting ambient air temperature in [degree C]
tr	a numeric value presenting mean radiant temperature in [degree C]
p	a numeric value presenting air permeability (low < 5, medium 50, high > 100 l/m ² s) in [l/m ² s]
w	a numeric value presenting walking speed (or calculated work created air movements) in [m/s]
v	a numeric value presenting relative air velocity(0.4 to 18 m/s) in [m/s]
rh	a numeric value presenting relative humidity [%]
clo	a numeric value presenting clothing insulation level in [clo]

Value

returns required recovery time in [hours]

Note

The authors disclaim all obligations and liabilities for damages arising from the use or attempted use of the information, including, but not limited to, direct, indirect, special and consequential damages, and attorneys' and experts' fees and court costs. Any use of the information will be at the risk of the user.

Author(s)

Developed by Ingvar Holmer and Hakan O. Nilsson, 1990 in java and transferred to R by Shoaib Sarwar. Further contribution by Marcel Schweiker.

References

ISO 11079, 2007-12-15, ERGONOMICS OF THE THERMAL ENVIRONMENT - DETERMINATION AND INTERPRETATION OF COLD STRESS WHEN USING REQUIRED CLOTHING INSULATION (IREQ) AND LOCAL COOLING EFFECTS

Examples

```
calcRT(90,0,25,25,8,0.2,0.4,50,1.5)
```

calcSET	<i>Standard Effective Temperature (SET)</i>
---------	---

Description

calcSET calculates Standard Effective Temperature based on the 2-Node-Model by Gagge et al.

Usage

```
calcSET(ta, tr, vel, rh, clo = .5, met = 1, wme = 0, sa = NULL, pb = 760,
ltime = 60, ht = 171, wt = 70, tu = 40, obj = "set", csw = 170, cdil = 120,
cstr = .5, bodyPosition = 'sitting')
```

Arguments

ta	a numeric value presenting air temperature in [degree C]
tr	a numeric value presenting mean radiant temperature in [degree C]
vel	a numeric value presenting air velocity in [m/s]
rh	a numeric value presenting relative humidity [%]
clo	a numeric value presenting clothing insulation level in [clo]
met	a numeric value presenting metabolic rate in [met]
wme	a numeric value presenting external work in [met]
sa	(optional) surface Area according to mosteller formula [m ²]
pb	a numeric value presenting barometric pressure in [torr] or [mmHg]
ltime	a numeric value presenting exposure time in [minutes]
ht	a numeric value presenting body height in [cm]
wt	a numeric value presenting body weight in [kg]
tu	a numeric value presenting turbulence intensity in [%]
obj	a character element, either "set" or "pmvadj"
csw	a numeric value presenting the driving coefficient for regulatory sweating
cdil	a numeric value presenting the driving coefficient for vasodilation
cstr	a numeric value presenting the driving coefficient for vasoconstriction
bodyPosition	a string representing body position, has to be 'sitting' or 'standing'. Default value is 'sitting'

Details

All variables must have the same length 1. For the calculation of several values use function `calcComfInd`. The value of `obj` defines whether the function will use the version presented in ASHRAE 55-2013 for adjustment of pmv (`obj = "pmvadj"`), or the original code by Gagge to calculate set (`obj = "set"`). In the version presented in ASHRAE 55-2013, the lines of code related to self-generated convection is deleted. Therefore, a difference can only be seen at higher values of `met`.

Value

`calcSET` returns the Standard Effective Temperature (SET)

Note

In case one of the variables is not given, a standard value will be taken from a list (see [createCond](#) for details).

Author(s)

The code for `calc2Node` is based on the code in BASIC and C++ presented by Fountain and Huizenga (1995). The translation into R-language and comparison with ASHRAE 55-2013 conducted by Marcel Schweiker.

References

ASHRAE Standard 55-2013. Thermal environmental conditions for human occupancy. American society of heating, Refrigerating and Air-Conditioning Engineering, Atlanta, USA, 2013.

Fountain & Huizenga (1995) A thermal sensation model for use by the engineering profession ASHRAE RP-781 Final report.

Gagge, Fobelets & Berglund (1986) A standard predictive index of human response to the thermal environment, ASHRAE transactions, 92 (2B), 709-731.

See Also

see also [calcComfInd](#)

Examples

```
## Using several rows of data:
ta <- c(20,22,24)
tr <- ta
vel <- rep(.15,3)
rh <- rep(50,3)

maxLength <- max(sapply(list(ta, tr, vel, rh), length))
SET <- sapply(seq(maxLength), function(x) { calcSET(ta[x], tr[x], vel[x], rh[x]) } )
```

calcSkinWettedness *Skin Wettedness based on the 2-Node-Model*

Description

calcSkinWettedness calculates Skin Wettedness based on the 2-Node-Model by Gagge et al.

Usage

```
calcSkinWettedness(ta, tr, vel, rh, clo = 0.5, met = 1, wme = 0, pb = 760,
ltime = 60, ht = 171, wt = 70, tu = 40, obj = "set", csw = 170, cdil = 120,
cstr = 0.5, varOut="skinWet")
```

Arguments

ta	a numeric value presenting air temperature in [degree C]
tr	a numeric value presenting mean radiant temperature in [degree C]
vel	a numeric value presenting air velocity in [m/s]
rh	a numeric value presenting relative humidity [%]
clo	a numeric value presenting clothing insulation level in [clo]
met	a numeric value presenting metabolic rate in [met]
wme	a numeric value presenting external work in [met]
pb	a numeric value presenting barometric pressure in [torr] or [mmHg]
ltime	a numeric value presenting exposure time in [minutes]
ht	a numeric value presenting body height in [cm]
wt	a numeric value presenting body weight in [kg]
tu	a numeric value presenting turbulence intensity in [%]
obj	a character element, either "set" or "pmvadj"
csw	a numeric value presenting the driving coefficient for regulatory sweating
cdil	a numeric value presenting the driving coefficient for vasodilation
cstr	a numeric value presenting the driving coefficient for vasoconstriction
varOut	a string value "skinWet" to report value of skin wettedness

Details

All variables must have the same length 1. For the calculation of several values use function calcComfInd. The value of obj defines whether the function will use the version presented in ASHRAE 55-2013 for adjustment of pmv (obj = "pmvadj"), or the original code by Gagge to calculate set (obj = "set"). In the version presented in ASHRAE 55-2013, the lines of code related to self-generated convection is deleted. Therefore, a difference can only be seen at higher values of met.

Value

calcSkinWettedness returns the Skin Wettedness

Note

In case one of the variables is not given, a standard value will be taken from a list (see [createCond](#) for details).

Author(s)

The code for calc2Node is based on the code in BASIC and C++ presented by Fountain and Huizenga (1995). The translation into R-language and comparison with ASHRAE 55-2013 conducted by Marcel Schweiker.

References

ASHRAE Standard 55-2013. Thermal environmental conditions for human occupancy. American society of heating, Refrigerating and Air-Conditioning Engineering, Atlanta, USA, 2013.

Fountain & Huizenga (1995) A thermal sensation model for use by the engineering profession ASHRAE RP-781 Final report.

Gagge, Fobelets & Berglund (1986) A standard predictive index of human response to the thermal environment, ASHRAE transactions, 92 (2B), 709-731.

See Also

see also [calcComfInd](#)

Examples

```
## Using several rows of data:
ta <- c(20,22,24)
tr <- ta
vel <- rep(.15,3)
rh <- rep(50,3)

maxLength <- max(sapply(list(ta, tr, vel, rh), length))
skinWet <- sapply(seq(maxLength), function(x) { calcSkinWettedness(ta[x], tr[x], vel[x], rh[x]) })
```

calcSolarGain

Solar Gain

Description

Function to calculate effective radiant field and delta mean radiant temperature.

Usage

```
calcSolarGain(solAlt, solAzi, solRadDir, solTrans,
  fSvv, fBes, asw=0.7, posture="seated", floorRef=0.6)
```

Arguments

solAlt	a numeric value presenting solar altitude, degrees from horizontal in [degree C]
solAzi	a numeric value presenting solar azimuth, degrees clockwise from North in [degree C]
solRadDir	a numeric value presenting direct-beam solar radiation [W/m2]
solTrans	a numeric value presenting total solar transmittance. Ranges from 0 to 1.
fSvv	a numeric value presenting fraction of sky vault exposed to body. Ranges from 0 to 1.
fBes	a numeric value presenting fraction of the possible body surface exposed to sun. Ranges from 0 to 1.
asw	a numeric value presenting the average short-wave absorptivity of the occupant.
posture	a list of available options 'standing', 'supine' or 'seated'.
floorRef	a numeric value presenting floor reflectance. Usually assumed to be constant and equal to 0.6.

Value

An array of two values First values represents erf - Net energy flux to or from the human body using the Effective Radiant Field [W/m2] Second value represents delMrt - Delta mean radiant temperature, the increase in radiant temperature required without solar radiation [Degree C]

Author(s)

Code implemented in to R by Shaomi Rahman. Further contribution by Marcel Schweiker.

References

Original code in Python by Tartarini & Schiavon (2020) <doi:10.1016/j.softx.2020.100578>

See Also

see also [calcComfInd](#)

Examples

```
calcSolarGain(0, 120, 800, 0.5, 0.5, 0.5, asw=0.7, posture="seated") # Returns [42.9, 10.3]
```

calctAdapt15251 *Adaptive Comfort or Neutral Temperatures*

Description

calctadapt are three functions to calculate adaptive comfort or neutral temperatures based on a given outdoor temperature value.

Usage

```
calctAdapt15251(trm = 20)
```

```
calctAdaptASHRAE(tmno)
```

```
calctnAuliciems(ta, tmno)
```

```
calctnHumphreysNV(tmno)
```

```
calctnHumphreysAC(tmno)
```

Arguments

trm	numerical value presenting the running mean outdoor temperature in [degree C].
ta	numerical value presenting the indoor air temperature in [degree C].
tmno	numerical value presenting the mean monthly outdoor temperature in [degree C].

Value

returns the adaptive comfort or neutral temperature with respect to the given outdoor temperature value

Note

The difference between calctnHumphreysNV and calctnHumphreysAC is that the former was found for natural ventilated buildings (NV), while the latter was found for climate-controlled buildings (AC).

Author(s)

Code implemented in to R by Marcel Schweiker. Further contribution by Sophia Mueller and Shoaib Sarwar.

References

calctAdapt15251 is based on DIN EN 15251 Indoor environmental input parameters for design and assessment of energy performance of buildings addressing indoor air quality, thermal environment, lighting and acoustics; German version EN 15251:2012 2012.

calcAdaptASHRAE is based on Brager & de Dear (2001) Climate, comfort, & natural ventilation: a new adaptive comfort standard for ASHRAE standard 55.

calctnAuliciems is based on Auliciems (1981) Psycho-physiological criteria for global thermal zones of building design.

calctnHumphreysNV and calctnHumphreysAC are based on Humphreys (1978) Outdoor temperatures and comfort indoors. Batiment International, Building Research and Practice, Taylor and Francis.

See Also

see also [calcComfInd](#)

Examples

```
## define variable
trm <- 21.2
## calculate adaptive comfort temperature
calctAdapt15251(trm)
```

calcTNZPDF

Values related to TNZ approach

Description

calcTNZPDF calculates the distance from the thermoneutral zone, either skin temperature or room air related. Also calculates the probability function (PDF) of the thermoneutral zone.

Usage

```
calcTNZPDF(ht, wt, age, gender, clo, vel, tskObs, taObs, met, rh,
fBasMet = "rosa", fSA = "duBois", percCov = 0, TcMin = 36, TcMax = 38,
plotZone = FALSE, gridTaMin = 20, gridTaMax = 30, gridTskMin = 30, gridTskMax = 42,
gridTa = 1000, gridTsk = 1000, sa = 1.86, IbMax = 0.124, IbMin = 0.03, alphaIn = 0.08,
metMin = 55.3, metMax = 57.3, metDiff = .1, forPDF = FALSE, metAdapt = "none",
trm = 15, TcPreAdapt = 37.2)
```

Arguments

ht	a numeric value presenting body height in [cm].
wt	a numeric value presenting body weight in [kg].
age	a numeric value presenting the age in [years].

gender	a numeric value presenting sex (female = 1, male = 2)
clo	a numeric value presenting clothing insulation level in [clo].
vel	a numeric value presenting air velocity in [m/s].
tskObs	a numeric value presenting actual mean skin temperature in [degree C].
taObs	a numeric value presenting actual air temperature in [degree C].
met	a numeric value presenting metabolic rate (activity related) in [met].
rh	a numeric value presenting realtive humidity in [%].
fBasMet	a string presenting the method of calculating basal metbolic rate. Needs to be one of "rosa", "harris", "miflin", "fixed", or "direct". Fixed will result in the value of 58.2 W/m2. Direct requires definition of metMin and metMax.
fSA	a string presenting the method of calculating the surface area. Needs to be one of "duBois", "mosteller", or "direct".
percCov	a numeric value between 0 and 1 presenting the percentage of the body covered by clothes in [%].
TcMin	a numeric value presenting the minimum allowed core temperature in [degree C].
TcMax	a numeric value presenting the maximum allowed core temperature in [degree C].
plotZone	a boolean variable TRUE or FALSE stating, wether TNZ should be plotted or not.
gridTaMin	a numeric value defining the minimum grid value for Ta, ambient temperature, in [degree C].
gridTaMax	a numeric value defining the maximum grid value for Ta, ambient temperature, in [degree C].
gridTskMin	a numeric value defining the minimum grid value for Tsk, skin temperature, in [degree C].
gridTskMax	a numeric value defining the maximum grid value for Tsk, skin temperature, in [degree C].
gridTa	a numeric value defining the grid size in Ta dimension.
gridTsk	a numeric value defining the grid size in Tsk dimension.
sa	a numeric value for surface area (only used with method fSA: direct) in [m2].
IbMax	a numeric value for maximum body tissue insulation in [m2K/W].
IbMin	a numeric value for minimum body tissue insulation in [m2K/W].
alphaIn	a numeric value for alpha (if 0, alpha will be calculated according to Fanger).
metMin	a numeric value for minimum metabolic rate (only used with method fBas-Met:direct) in [W/m2].
metMax	a numeric value for maximum metabolic rate (only used with method fBas-Met:direct) in [W/m2].
metDiff	a numeric value for difference between minimum and maximum metabolic rate (not used with method fBasMet:direct) in [W/m2].

forPDF	a boolean value. If TRUE, matrix for drawing of PDF will be output, if FALSE, values for dTNZ and others will be output.
metAdapt	a string presenting the method of calculating the surface area. Needs to be one of 'Hori', 'Q10', 'ATHB', or 'none'. NOTE: all methods applied here still in development and need further validation.
trm	numerical value presenting the running mean outdoor temperature in [degree C]. Only used with metAdapt: Hori and ATHB.
TcPreAdapt	numerical value presenting the initial core temperature before adaptation in [degree C]. Only used with metAdapt: Q10.

Details

The percentage of the body covered by clothes can be estimated e.g. based on ISO 9920 Appendix H (Figure H.1). A typical winter case leads to a value of around .86, in the summer case this goes down to values around .68.

Value

calcTNZPDF returns either a dataframe suitable to draw the pdf of TNZ (by setting forPDF to TRUE) or a dataframe with the columns dTNZ, dTNZTs, dTNZTa and others. Thereby

dTNZ	The absolute distance to the centroid of the thermoneutral zone
dTNZTs	Relative value of distance assuming skin temperature to be dominant for sensation
dTNZTa	Relative value of distance assuming ambient temperature to be dominant for sensation

Note

This function was used for the review paper by Schweiker et al. (2018) (see reference above). Some of the equations implemented are still to be validated further - therefore, use this function and its parameters with great care.

This function is not (yet) implemented in calcComfInd, calcdTNZ is applied there.

Author(s)

Marcel Schweiker and Boris Kingma

References

Schweiker, Huebner, Kingma, Kramer & Pallubinsky (2018) <doi:10.1080/23328940.2018.1534490>
 Kingma, Schweiker, Wagner & van Marken Lichtenbelt Exploring the potential of a biophysical model to understand thermal sensation Proceedings of 9th Windsor Conference: Making Comfort Relevant Cumberland Lodge, Windsor, UK, 2016. Kingma & van Marken Lichtenbelt (2015) <doi:10.1038/nclimate2741>
 Kingma, Frijns, Schellen & van Marken Lichtenbelt (2014) <doi:10.4161/temp.29702>

See Also

[calcdTNZ](#)

Examples

```
## Calculate and draw pdf of TNZ for a young non-obese male
longTcYoungMale <- calcTNZPDF(ht = 178, wt = 70, age = 30, gender = 2, clo = 0.5,
  vel = 0.2, tskObs = 36.2, taObs = 26, met = 1,
  rh = 50, fBasMet = "rosa", fSA = "duBois", percCov = 0.6,
  TcMin = 36, TcMax = 38, plotZone = FALSE, gridTaMin = 20, gridTaMax = 30,
  gridTskMin = 20, gridTskMax = 42, gridTa = 1000, gridTsk = 1000,
  sa = 2.0335, IbMax = 0.124, IbMin = 0.03, alphaIn = 0, metMin = 55.3,
  metMax = 57.3, metDiff = 0.1, forPDF = TRUE)

plot(density(longTcYoungMale$X2), main="", xlim=c(14,36), ylim=c(0,.50),
  xlab="Operative temperature [degree C]")
```

calcTPRTSV	<i>True Positive Rate between Predicted and Actual Thermal Sensation Vote</i>
------------	---

Description

calcTPRTSV calculates the true positive rate between predicted thermal sensation votes and actual obtained sensation votes

Usage

```
calcTPRTSV(ref, pred)
```

Arguments

ref	a numeric item or vector containing categorical actual thermal sensation votes coded from -3 'cold' to +3 'hot'
pred	a numeric item or vector containing categorical predicted thermal sensation votes coded from -3 'cold' to +3 'hot'

Value

calcTPRTSV returns a single value presenting the true positive rate between actual and predicted thermal sensation votes.

Author(s)

Marcel Schweiker

References

Schweiker & Wagner (2015) <doi:10.1016/j.buildenv.2015.08.018>

See Also

see also [calcMeanBias](#), [calcAvgAcc](#)

Examples

```
## Define data
ref <- rnorm(5) # actual thermal sensation votes
ref <- cutTSV(ref)
pred <- rnorm(5) # predicted thermal sensation votes
pred <- cutTSV(pred)
calcTPRTSV(ref, pred)
```

calcTroin

Radiative and Operative Temperature

Description

The functions calcTroin calculates radiative and operative temperature based on air temperature, globe temperature, air velocity and metabolic rate. Globe temperature needs to be measured using a standard globe with a diameter of 0.15m and an emissivity of .95 (black coloured).

Usage

```
calcTroin(vel, tg, ta, met)
```

```
calctroin(vel, tg, ta, met)
```

```
Troin(vel, tg, ta, met)
```

```
troin(vel, tg, ta, met)
```

Arguments

vel	a numeric value presenting air velocity in [m/s]
tg	a numeric value or vector presenting the globe temperature in [degree C]
ta	a numeric value presenting air temperature in [degree C]
met	a numeric value presenting metabolic rate in [met]

Details

Calculation of the radiative temperature is based on ISO 7726:2001, equation (9). Calculation of operative temperature is based on ISO 7726:2001, Appendix G.3. The adjustment of air velocity to present relative air velocity based on metabolic rate is based on ISO 7730:2005 Appendix C.2.

Value

calcTroin returns a data.frame with radiative and operative temperature.

Author(s)

Marcel Schweiker. Further contribution by Shoaib Sarwar.

References

ISO 7726 Ergonomics of the Thermal Environment, Instruments for measuring Physical Quantities Geneva: International standard Organization, 1998.

ISO 7730 Ergonomics of the thermal environment - analytical determination and interpretation of thermal comfort using calculation of the pmv and ppd indices and local thermal comfort criteria 2005.

Examples

```
## Note: Due to random generated asv values. The values for the coefficients will not be meaningful.
## Create sample data
ta <- 20:24      # vector with air temperature values
vel <- rep(.1,5) # vector with air velocities
met <- rep(1.1,5) # vector with metabolic rates
tg <- 25:29      # vector with globe temperature values

calcTroin(vel, tg, ta, met)
```

calcTSens

Predicted Thermal Sensation based on the 2-Node-Model

Description

calcTSens calculates Predicted Thermal Sensation based on the 2-Node-Model by Gagge et al.

Usage

```
calcTSens(ta, tr, vel, rh, clo = 0.5, met = 1, wme = 0, pb = 760, ltime = 60,
ht = 171, wt = 70, tu = 40, obj = "set", csw = 170, cdil = 120, cstr = 0.5)
```

Arguments

ta	a numeric value presenting air temperature in [degree C]
tr	a numeric value presenting mean radiant temperature in [degree C]
vel	a numeric value presenting air velocity in [m/s]
rh	a numeric value presenting relative humidity [%]
clo	a numeric value presenting clothing insulation level in [clo]
met	a numeric value presenting metabolic rate in [met]
wme	a numeric value presenting external work in [met]
pb	a numeric value presenting barometric pressure in [torr] or [mmHg]
ltime	a numeric value presenting exposure time in [minutes]
ht	a numeric value presenting body height in [cm]
wt	a numeric value presenting body weight in [kg]
tu	a numeric value presenting turbulence intensity in [%]

obj	a character element, either "set" or "pmvadj"
csw	a numeric value presenting the driving coefficient for regulatory sweating
cdil	a numeric value presenting the driving coefficient for vasodilation
cstr	a numeric value presenting the driving coefficient for vasoconstriction

Details

All variables must have the same length 1. For the calculation of several values use function `calcComfInd`. The value of `obj` defines whether the function will use the version presented in ASHRAE 55-2013 for adjustment of `pmv` (`obj = "pmvadj"`), or the original code by Gagge to calculate `set` (`obj = "set"`). In the version presented in ASHRAE 55-2013, the lines of code related to self-generated convection is deleted. Therefore, a difference can only be seen at higher values of `met`.

Value

`calcTSens` returns the Predicted Thermal Sensation

Note

In case one of the variables is not given, a standard value will be taken from a list (see [createCond](#) for details).

Author(s)

The code for `calc2Node` is based on the code in BASIC and C++ presented by Fountain and Huizenga (1995). The translation into R-language and comparison with ASHRAE 55-2013 conducted by Marcel Schweiker.

References

ASHRAE Standard 55-2013. Thermal environmental conditions for human occupancy. American society of heating, Refrigerating and Air-Conditioning Engineering, Atlanta, USA, 2013.

Fountain & Huizenga (1995) A thermal sensation model for use by the engineering profession ASHRAE RP-781 Final report.

Gagge, Fobelets & Berglund (1986) A standard predictive index of human response to the thermal environment, ASHRAE transactions, 92 (2B), 709-731.

See Also

see also [calcComfInd](#)

Examples

```
## Using several rows of data:  
ta <- c(20,22,24)  
tr <- ta  
vel <- rep(.15,3)  
rh <- rep(50,3)
```

```
maxLength <- max(sapply(list(ta, tr, vel, rh), length))
TSens <- sapply(seq(maxLength), function(x) { calcTSens(ta[x], tr[x], vel[x], rh[x]) } )
```

calcTWC	<i>Windchill temperature (TWC)</i>
---------	------------------------------------

Description

Function to calculate windchill temperature, TWC, in Degrees.

Usage

```
calcTWC(v, ta)

windchill(v, ta)
```

Arguments

v	a numeric value presenting meteorological wind speed (at 10 m) in [km/h]
ta	a numeric value presenting ambient air temperature in [degree C]

Details

The function returns the temperature that considers the cooling effect on a localized skin segment.

Value

returns (twc) Wind chill temperature in [Degree C]

Note

The authors disclaim all obligations and liabilities for damages arising from the use or attempted use of the information, including, but not limited to, direct, indirect, special and consequential damages, and attorneys' and experts' fees and court costs. Any use of the information will be at the risk of the user.

Author(s)

Developed by Ingvar Holmer and Hakan O. Nilsson, 1990 in java and transferred to R by Shoaib Sarwar. Further contribution by Marcel Schweiker.

References

ISO 11079, 2007-12-15, ERGONOMICS OF THE THERMAL ENVIRONMENT - DETERMINATION AND INTERPRETATION OF COLD STRESS WHEN USING REQUIRED CLOTHING INSULATION (IREQ) AND LOCAL COOLING EFFECTS

Examples

```
calcTWC(6.8, -25)
```

`calcUTCI`*Universal Thermal Comfort Index (UTCI)*

Description

Functions to calculate UTCI.

Usage

```
calcUTCI(ta, tr, vel, rh)
```

Arguments

<code>ta</code>	a numeric value presenting air temperature in [degree C]
<code>tr</code>	a numeric value presenting mean radiant temperature in [degree C]
<code>vel</code>	a numeric value presenting air velocity in [m/s]
<code>rh</code>	a numeric value presenting relative humidity [%]

Details

air temperature and mean radiant temperature should be in Degree C unit. Air velocity has to be in m/s unit and relative humidity has to be put in percentage value.

Value

the `utciValue` value rounded to one decimal

Author(s)

Code implemented in to R by Shaomi Rahman. Further contribution by Marcel Schweiker.

References

UTCI project page on <http://www.utci.org/> Original code in Python by Tartarini & Schiavon (2020) <doi:10.1016/j.softx.2020.100578>

See Also

see also [calcComfInd](#)

Examples

```
calcUTCI(25, 25, 1.0, 50) # Returns 24.6
```

`calcVTG`*PPD with Vertical Air Temperature Gradient*

Description

Function to calculate vertical air temperature gradient using the predicted percentage of dissatisfied.

Usage

```
calcVTG(ta, tr, vel, rh, clo, met, v_tmp_grad)
```

Arguments

<code>ta</code>	a numeric value presenting air temperature in [degree C]
<code>tr</code>	a numeric value presenting mean radiant temperature in [degree C]
<code>vel</code>	a numeric value presenting air velocity in [m/s]
<code>rh</code>	a numeric value presenting relative humidity [%]
<code>clo</code>	a numeric value presenting clothing insulation level in [clo]
<code>met</code>	a numeric value presenting metabolic rate in [met]
<code>v_tmp_grad</code>	vertical temperature gradient between the feet and the head [degree C/m]

Details

Calculates the percentage of thermally dissatisfied persons with a vertical temperature gradient between feet and head. Applicable only for velocity(vel) < 0.2 m/s

Value

Predicted Percentage of Dissatisfied with vertical temperature gradient in [%]
Acceptability in [boolean]

Author(s)

Code implemented in to R by Shoaib Sarwar. Further contribution by Marcel Schweiker.

References

Original code in Python by Tartarini & Schiavon (2020) <doi:10.1016/j.softx.2020.100578>

Examples

```
calcVTG(25,25,0.1,50,0.5,1.2,7)  
# returns Vertical Air Temperature Gradient:12.4, Acceptability:FALSE
```

createCond

*Creating a List with Standard Values***Description**

createCond creates a list with standard variables to be used as an input parameter for calculating comfort indices using the function calcComfInd.

Usage

```
createCond(a = TRUE)
```

```
createcond(a = TRUE)
```

Arguments

a logical. If a = TRUE, function returns a list of standard conditions. If a = FALSE, function returns a list of empty variables which may be edited manually. See details for further information.

Details

lsstrd and lsEmpty contain the following elements

Variable name	values in lsstrd	values in lsEmpty	description
ta	25	NA	Air temperature in (degree C)
tr	25	NA	mean radiant temperature in (degree C)
vel	.1	NA	Air velocity (m/s)
rh	50	NA	Relative Humidity (%)
clo	.5	NA	clothing (do)
met	1	NA	metabolic rate (met)
wme	0	NA	External work (met)
tu	40	NA	turbulence intensity (%)
tmmo	15	NA	mean monthly outdoor temperature in (degree C)
ltime	60	NA	Exposure time (min)
pb	760	NA	Barometric pressure (torr)
wt	70	NA	weight (Kg)
ht	171	NA	height (cm)
trm	15	NA	Running mean outdoor temperature in (degree C)
age	21	NA	age (years)
gender	1	NA	gender (female = 1)
tsk	35	NA	mean skin temperature in (degree C)
psych	-1.4	NA	factor related to fixed effect on perceived control
apCoeff	.293	NA	adaptive coefficient for pmv
epCoeff	.9	NA	expectancy factor for pmv
asCoeff	.2	NA	adaptive coefficient for set
esCoeff	1.3	NA	expectancy factor for set

asv	1.5	NA	actual sensation vote (0 = neutral)
tao	5	NA	outdoor air temperature
rho	70	NA	outdoor relative humidity
frad	.7	NA	0.7(for seating), 0.73(for standing) [-]
eps	.95	NA	emissivity [-]
ic	1.085	NA	1.084 (average permeability), 0.4 (low permeability)
tcr	37	NA	initial values for core temp
tsk	36	NA	initial values for skin temperature
basMet	58.2	NA	basal metabolic rate
warmUp	60	NA	length of warm up period, i.e. number of times, loop is running for H
cdil	100	NA	value for cdil in 2-node model of Gagge (applied in calculation of H
sigmatr	.25	NA	value for cdil in 2-node model of Gagge (applied in calculation of H

Value

lsstrd	List, which is created for a = TRUE; contains standard conditions.
lsEmpty	List, which is created for a = FALSE; contains empty variables to be modified manually.

indices listed as request. For details see details above.

Author(s)

Sophia Mueller and Marcel Schweiker.

References

For references see individual functions.

See Also

see also [calcComfInd](#)

Examples

```
## Creating list with standard variables
createCond()
## Creating list with empty values
createCond(a = FALSE)
```

Description

cutTSV converts continuous thermal sensation votes to categorical ones.

Usage

```
cutTSV(pred)
```

Arguments

pred a numeric item or vector containing continuous thermal sensation votes coded from -3 'cold' to +3 'hot'

Details

Categorization is realized with intervals closed on the right, e.g. setting all values lower and equal than -2.5 to a value of -3, higher than -2.5 and lower or equal -1.5 to -2, and so on.

Value

cutTSV returns an item or a vector with categorical thermal sensation votes.

Author(s)

Marcel Schweiker

Examples

```
## define example data
pred <- rnorm(5)
## bin values
cutTSV(pred)
```

dfASHRAETableG11

Calibration data for SET

Description

Data from ASHRAE 55-2013 to calibrate values given by SET model

Usage

```
data(dfASHRAETableG11)
```

Format

A data frame with 22 rows and 11 variables:

ta a numeric vector of air temperature [degree C]

taF a numeric vector of air temperature [degree F]

tr a numeric vector of radiant temperature [degree C]

trF a numeric vector of radiant temperature [degree F]

vel a numeric vector of indoor air velocity [m/s]
velFPM a numeric vector of indoor air velocity [fpm]
rh a numeric vector of relative humidity [%]
met a numeric vector of metabolic rate [MET]
clo a numeric vector of clothing insulation level [CLO]
set a numeric vector of standard effective temperature (SET) [degree C]
setF a numeric vector of standard effective temperature (SET) [degree F]

References

ASHRAE Standard 55-2013. Thermal environmental conditions for human occupancy. American society of heating, Refrigerating and Air-Conditioning Engineering, Atlanta, USA, 2013.

Examples

```
data(dfASHRAETableG11)
head(dfASHRAETableG11)
```

dfField	<i>Field data example</i>
---------	---------------------------

Description

Randomly sampled data from a field study campaign with data from 156 samples. For further description, see the reference given.

Usage

```
data(dfField)
```

Format

A data frame with 156 rows and 9 variables:

ta air temperature [degree C]
tr radiant temperature [degree C] - same as ta
rh relative humidity [%]
trm running mean outdoor temperature [degree C]
clo clothing insulation level [CLO]
tao outdoor air temperature [degree C]
vel indoor air velocity [m/s]
met metabolic rate [MET]
asv actual thermal sensation vote on ASHRAE scale []

References

Schweiker, M. and Wagner, A. Exploring potentials and limitations of the adaptive thermal heat balance framework. Proceedings of 9th Windsor Conference: Making Comfort Relevant Cumberland Lodge, Windsor, UK, 2016. <<https://windsorconference.com/>>

Examples

```
data(dfField)
head(dfField)
```

dfISO7730AppE

Calibration data for PMV

Description

Data from ISO 7730 Appendix E to calibrate values given by PMV model

Usage

```
data(dfISO7730AppE)
```

Format

A data frame with 13 rows and 8 variables:

top a numeric vector of operative temperature [degree C]

vel a numeric vector of indoor air velocity [m/s]

rh a numeric vector of relative humidity [%]

met a numeric vector of metabolic rate [MET]

clo a numeric vector of clothing insulation level [CLO]

pmv a numeric vector of Predicted mean vote (PMV)

References

ISO 7730 Ergonomics of the thermal environment analytical determination and interpretation of thermal comfort using calculation of the pmv and ppd indices and local thermal comfort criteria 2005.

Examples

```
data(dfISO7730AppE)
head(dfISO7730AppE)
```

dfISO7730TableD1	<i>Calibration data for PMV and PPD</i>
------------------	---

Description

Data from ISO 7730 to calibrate values given by PMV / PPD model

Usage

```
data(dfISO7730TableD1)
```

Format

A data frame with 13 rows and 8 variables:

ta a numeric vector of air temperature [degree C]

tr a numeric vector of radiant temperature [degree C]

vel a numeric vector of indoor air velocity [m/s]

rh a numeric vector of relative humidity [%]

met a numeric vector of metabolic rate [MET]

clo a numeric vector of clothing insulation level [CLO]

pmv a numeric vector of Predicted mean vote (PMV)

ppd a numeric vector of Predicted percentage dissatisfied (PPD)

References

ISO 7730 Ergonomics of the thermal environment analytical determination and interpretation of thermal comfort using calculation of the pmv and ppd indices and local thermal comfort criteria 2005.

Examples

```
data(dfISO7730TableD1)
head(dfISO7730TableD1)
```

dfISO7933AppF

*Calibration data for Tre, SWtotg, Dlimtre, Dlimloss50, Dlimloss95***Description**

Data from ISO 7933 Appendix F to calibrate values given by the proposed model

Usage

```
data(dfISO7933AppF)
```

Format

A data frame with 10 rows and 16 variables:

acc1 a numeric vector of state of acclimatised subject, 100 if acclimatised, 0 otherwise [-]

posture a numeric vector of posture of subject, posture = 1 sitting, =2 standing, =3 crouching [-]

Ta a numeric vector of air temperature [degree C]

Pa a numeric vector of partial water vapour pressure [kPa]

Tr a numeric vector of mean radiant temperature [degree C]

Va a numeric vector of air velocity (m/s)

Met a numeric vector of metabolic rate (W/(m*m))

Ic1 a numeric vector of static thermal insulation (clo)

THETA a numeric vector of angle between walking direction and wind direction (degrees)

Walksp a numeric vector of walking speed (m/s)

Duration a numeric vector of the duration of the work sequence (min)

Tre a numeric vector of final rectal temperature (degree C)

SWtotg a numeric vector of total water loss (g)

Dlimtre a numeric vector of maximum allowed exposition time for heat storage (min)

Dlimloss50 a numeric vector of maximum water loss for protection of an average person (g)

Dlimloss95 a numeric vector of maximum water loss for protection of 95% of the working people (g)

References

ISO 7933 Ergonomics of the thermal environment - Analytical determination and interpretation of heat stress using calculation of the predicted heat strain 2004

Examples

```
data(dfISO7933AppF)
head(dfISO7933AppF)
```

`dfUTCIValues`*Dataset with Different Combinations of Inputs to Calculate UTCI*

Description

Dataset with Different Combinations of Inputs to Calculate UTCI

Usage

```
data(dfUTCIValues)
```

Format

A data frame with 81 rows and 5 variables:

`ta` a numeric value presenting air temperature in [degree C]

`tr` a numeric value presenting mean radiant temperature in [degree C]

`vel` a numeric value presenting air velocity in [m/s]

`rh` a numeric value presenting relative humidity [%]

`utci` a numeric value presenting the UTCI value

See Also

see also [calcUTCI](#)

Examples

```
data(dfUTCIValues)
head(dfUTCIValues)
```

Index

- * **datasets**
 - dfASHRAETableG11, 80
 - dfField, 81
 - dfISO7730AppE, 82
 - dfISO7730TableD1, 83
 - dfISO7933AppF, 84
 - dfUTCIVvalues, 85
- * **manip**
 - calcTPRTSV, 71
 - cutTSV, 79
- * **package**
 - comf-package, 3
 - 2Node (calc2Node), 4
 - 2node (calc2Node), 4
- ad (calcAD), 6
- ankledraft (calcAD), 6
- aPMV (calcaPMV), 7
- apmv (calcaPMV), 7
- AvgAcc (calcAvgAcc), 16
- avgacc (calcAvgAcc), 16
- bias (calcBias), 17
- calc2Node, 4, 22, 58, 60
- calcAD, 6
- calcapCoeff, 8
- calcapCoeff (calcepCoeff), 26
- calcaPMV, 7, 27
- calcasCoeff (calcepCoeff), 26
- calcATHBpmv, 9
- calcATHBpmv2015, 10, 22
- calcATHBpts, 11
- calcATHBset, 12
- calcATHBstandard, 14
- calcATHBx, 15
- calcAvgAcc, 16, 18, 71
- calcavgacc (calcAvgAcc), 16
- calcBias, 17
- calcbias (calcBias), 17
- calcCE, 19
- calcCOEFF (calcepCoeff), 26
- calcComfInd, 4, 6, 8, 10–14, 16, 20, 23, 25, 28, 30, 33, 36, 45, 49, 50, 52, 55, 57, 58, 60, 63, 65, 66, 68, 74, 76, 79
- calcDewp (calcMixR), 41
- calcDisc, 22
- calcdisc (calcDisc), 22
- calcdTNZ, 22, 24, 70
- calcEnth (calcMixR), 41
- calcepCoeff, 26, 28
- calcePMV, 27, 27
- calcesCoeff (calcepCoeff), 26
- calcET, 29
- calcet (calcET), 29
- calcHbExSteady, 22, 31
- calcHbExUnsteady, 33, 33
- calcHumidity (calcMixR), 41
- calcHumx (calcMixR), 41
- calcIREQ, 36
- calcireq (calcIREQ), 36
- calcIso7933, 38
- calcMeanBias, 17, 71
- calcMeanBias (calcBias), 17
- calcMixR, 41
- calcMRTglobe, 43
- calcPD, 44
- calcpd (calcPD), 44
- calcPMV, 45
- calcPMVadj, 22, 47
- calcPMVGagge, 48
- calcPMVPPD, 22, 49
- calcPMVStar, 51
- calcPPD, 52
- calcPS, 54
- calcps (calcPS), 54
- calcPTS, 55
- calcpts (calcPTS), 55
- calcPtsa, 22, 27, 57

- calcptsa (calcPtsa), 57
- calcPtse, 27, 59
- calcptse (calcPtse), 59
- calcRH (calcMixR), 41
- calcRT, 61
- calcrt (calcRT), 61
- calcSdBias (calcBias), 17
- calcSeBias (calcBias), 17
- calcSET, 62
- calcSkinWettedness, 64
- calcSolarGain, 65
- calcsolargain (calcSolarGain), 65
- calcSVP (calcMixR), 41
- calctAdapt, 22
- calctAdapt (calctAdapt15251), 67
- calctadapt (calctAdapt15251), 67
- calctAdapt15251, 67
- calctAdaptASHRAE (calctAdapt15251), 67
- calctnAuliciens (calctAdapt15251), 67
- calctnHumphreysAC (calctAdapt15251), 67
- calctnHumphreysNV (calctAdapt15251), 67
- calcTNZPDF, 25, 68
- calcTPRTSV, 17, 18, 71
- calcTroin, 72
- calctroin (calcTroin), 72
- calcTSens, 73
- calcTWC, 75
- calctwc (calcTWC), 75
- calcUTCI, 76, 85
- calcutci (calcUTCI), 76
- calcVapourpressure (calcMixR), 41
- calcVP (calcMixR), 41
- calcVTG, 77
- ce (calcCE), 19
- clacTNZ (calcTNZPDF), 68
- comf (comf-package), 3
- comf-package, 3
- comfind (calcComfInd), 20
- coolingeffect (calcCE), 19
- createCond, 4, 6, 8, 21, 23, 25, 26, 28, 30, 45, 49, 52, 55, 56, 58, 60, 63, 65, 74, 78
- createcond (createCond), 78
- cutTSV, 79

- dfASHRAETableG11, 80
- dfField, 81
- dfISO7730AppE, 82
- dfISO7730TableD1, 83
- dfISO7933AppF, 84

- dfUTCIVValues, 85
- Disc (calcDisc), 22
- disc (calcDisc), 22

- ePMV (calcePMV), 27
- epmv (calcePMV), 27
- ET (calcET), 29
- et (calcET), 29
- exunsteady (calcHbExUnsteady), 33

- Gagge (calcPMVGagge), 48

- HbEx (calcHbExSteady), 31
- HbExSteady (calcHbExSteady), 31
- Hbexsteady (calcHbExSteady), 31
- hbexunsteady (calcHbExUnsteady), 33

- IREQ (calcIREQ), 36
- ireq (calcIREQ), 36

- MeanBias (calcBias), 17
- meanBias (calcBias), 17
- meanbias (calcBias), 17

- PD (calcPD), 44
- pd (calcPD), 44
- pmv (calcPMV), 45
- PMVadj (calcPMVadj), 47
- pmvadj (calcPMVadj), 47
- PMVGagge (calcPMVGagge), 48
- pmvppd (calcPMVPPD), 49
- PMVStar (calcPMVStar), 51
- ppd (calcPPD), 52
- PS (calcPS), 54
- ps (calcPS), 54
- PTS (calcPTS), 55
- pts (calcPTS), 55
- Ptsa (calcPtsa), 57
- ptsa (calcPtsa), 57
- Ptse (calcPtse), 59
- ptse (calcPtse), 59

- RT (calcRT), 61
- rt (calcRT), 61

- SET (calcSET), 62
- skin (calcSkinWettedness), 64
- skinWettedness (calcSkinWettedness), 64
- SolarGain (calcSolarGain), 65
- solargain (calcSolarGain), 65

star (calcPMVStar), 51

tadapt (calctAdapt15251), 67
tAdapt15251 (calctAdapt15251), 67
tAdaptASHRAE (calctAdapt15251), 67
tnAuliciems (calctAdapt15251), 67
tnHumphreysAC (calctAdapt15251), 67
tnHumphreysNV (calctAdapt15251), 67
TNZPDF (calcTNZPDF), 68
tnzpdf (calcTNZPDF), 68
TPDF (calcTNZPDF), 68
tpdf (calcTNZPDF), 68
TPR (calcTPRTSV), 71
tpr (calcTPRTSV), 71
Troin (calcTroin), 72
troin (calcTroin), 72
TSens (calcTSens), 73
TWC (calcTWC), 75
twc (calcTWC), 75

UTCI (calcUTCI), 76
utci (calcUTCI), 76

vairtegrad (calcVTG), 77
vairtmpgrad (calcVTG), 77
vtg (calcVTG), 77

wettedness (calcSkinWettedness), 64
windchill (calcTWC), 75